

Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)

Project Engineering
Management



Ref. No. PE/PG/SG5/E-4425/14-01

Enquiry No.: PE/PG/S G5/E-4425/14 dated 21-05-2014

Date: 27-06-2014

2x660 MW SURATGARH STPS STAGE-V
ELECTRIC HOISTS

CORRIGENDA/ADDENDA-3

Dear Sirs,

Following may be noted against tender enquiry no-PE/PG/S G5/E-4425/14 dated 21-05-2014

"The Gas Group shall be IIA/IIB for S.No. 1.11 Electric Hoist i.e. (1 No. Electric Hoist of 3 T cap, 8.5 m lift, 30m runway length (straight path) for HFO UNLOADING (Hazardous Area - Zone 1 as per IS 5572) with all accessories including isolating switch, DSL, VVVF drives for travel and hoist etc.). The vendor is requested to provide suitable flame-proof motor as per the specification."

Thanking you,
Yours faithfully,
For and on behalf of BHEL

Netrapal
27/06/14

NETRAPAL SINGH
ENGINEER/PGII-1

NETRAPAL SINGH
ENGINEER/PG-II-1,
BHEL/PS-PEM
POWER PROJECT ENGINEERING INSTITUTE,
PLOT NO. 25, SECTOR - 16A, NOIDA (UP)
(OFF) 0120-4368900

Regd. Office:
BHEL House
Siri Fort
New Delhi-110049