



BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-11-Aug-20

CORRIGENDUM- 03

<b>PROJECT</b>	:	3X200+3X500+1X500 MW NTPC KORBA TPP-FGD
<b>PACKAGE</b>	:	<b>MISC. TANKS(SITE FABRICATED)</b>
<b>ENQUIRY NO</b>	:	PE/PG/KR1/E-6469/2020 Dated. 09.07.2020
<b>SUBJECT</b>	:	<b>PRE-BID CLARIFICATION + DUE DATE EXTENSION</b>

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input type="checkbox"/>

In reference to the above mentioned tender enquiry for **MISC. TANKS(SITE FABRICATED)** package

Please note the following.

1. All bidders are requested to go through the attached pre-bid clarification.
2. Due date for offer submission has been extended from 11/08/2020 to 18/08/2020 (till 11:00 am) and P1 shall be opened on 18/08/2020 at 1:30 PM.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Guru Das  
Manager

**PRE BID CLARIFICATION SCHEDULE**

Tender reference	PE/PG/KR1/E-6469/2020					
Project:	3X200+3X500+1X500 MW NTPC KORBA TPP-FGD					
Package:	MISC.TANKS (SITE FABRICATED)					
Bidder:						
Sl.No.	Section / Part/Subsection	Page No.	Clause No.	Bid Specification	Bidder's Query	Purchaser's Reply
1	PE-TS-466-167-A101 / SECTION-I / Sub Section-C1-A / 3.0 DESIGN CONSIDERATIONS	87 of 391	3.6	In calculating the minimum plate thickness, the specific gravity of the liquid shall be taken as per tank schedule (Section-III, Annexure-8).	In the referred tank schedule, specific gravity of slurry and specific gravity of Lime Stone & Gypsum are given (Refer sl.no. 11(i).h & 11(i).i of tank schedule). Both are having different values. Please clarify which specific gravity shall be considered for calculating the plate thickness.	Bidder to consider specific gravity of slurry for calculating the plate thickness.