



Ref: E-5108/2015/CORRIGENDUM/01

Date: 21/11/2015

Our Ref:

- (i) Enq No.: -PE/PG/MG1/E-5108/2015 dated 05.11.2015

Subject: CORRIGENDUM REGARDING LT PVC CONTROL CABLE: 4X270 MW BHADRADRI TPS

With reference to above enquiry number and subject matter please find the following:

- Clause no. 1 of Price variation Formula: Variation for Polymer compound shall also be applicable.
- At the time of claiming freight charges by successful bidder please be clarified that Percentage of Freight Charges shall be applicable on ordered total ex-works value.

Please submit your best offer considering the above.

Thanking You

With regards
For & on behalf of BHEL

Sujeet Kumar
Sr. Engineer | PG II-2, BHEL PEM | Noida
E-MAIL: sujeetkumar@bhhelpem.co.in
Ph. No. +91-120-4368740

कृपया प्रेषित करें :	Please reply to :	फ़ोन Phone No:
बीएचईएल, पीएस-पीइएम	BHEL, PS-PEM,	91-120 - 436 8960
पीपीइआई भवन	PPEI Building,	
प्लॉट नं २५, सेक्टर १६ ए	Plot No.25, Sector 16A,	
नोएडा - २०१ ३०१ उ प्र	Noida-201301 (U.P.)	
भारत	INDIA	

पंजीकृत कार्यालय	Registered Office :
बीएचईएल हाउस	BHEL House,
सीरी फोर्ट	Siri Fort,
नयी दिल्ली - ११० ०४९	New Delhi-110049
भारत	INDIA