

**CORRIGENDUM -3 TO TENDER SPECIFICATION BHEL PSSR SCT 1502,dt:10/7/2012**

Sub:Erection, Testing and Commissioning including Supply and Application of Final Painting of Cooling Water Piping, Boiler , Rotating Machines, ESP, and Application of Refractory & Insulation in Unit-3 of 1 x 700 MW set at Bellary Thermal Power Station, Kudatini, Bellary Dist, Karnataka

**One of the bidder asought clsrifications on the subjek tender and the clarifications are furnished below for information**

SLNO	REF IN TENDER	QUERY	BHEL REPLY
1	NIT and CL1.2.0.Scope of work of TCC.The work of power cycle piping included in the scope of work	There is no column for rates of Power Cycle Piping in the rate schedule.Please clarify whether PCP is in the scope of work or not?	Erection of Power Cycle Piping is not included in this package
2	CL 1.3.10.4.2 of TCC .Only tig welding wire for CS,AS,SS welding for P91/P92 will be supplied by BHEL free of cost.	Please clarify that filler wire and electrodes for T-91 & T-22 material shall also be supplied by BHEL free of cost	Refer CL 4.1.4 in Chapter 4 of SCC,Volume 1B, Book-2.This Clause is applicable for P92/T92 also.
3	CL 1.4.1 (b) of TCC.In the event of providing hired crane	Please confirm that the crane operator for BHEL hired cranes shall also be provided free of cost	Refer Note -3 in Chapter -4 of TCC.
4	Clause 2.3.58.57,CL 2.7.63 of And CL 1.7.9 of TCC. CI 2.3.58.57 Contractor shall arrange and provide all temporary piping .....will be paid at quoted rate for erection CL 2.7.63.0 shows that all material required for hydro test acid cleaning SB etc will be supplied by BHEL free of cost CL 1.7.9 installation of temp piping	1.Please confirm that under which item rate schedule the payment of temp piping will be made. 2.Also confirm that material for temp piping shall be supplied by BHEL free of cost 3.There is no mention about percentage of payments of temp piping .Pl clarify	(1).CI 2.3.58.57 is applicable for CW piping.No separate payment will be made for temporary piping. (2).2.7.63.0 All items / material required for conducting hydraulic test, alkali boil out, acid cleaning/EDTA cleaning steam blowing etc., will be supplied by BHEL free of cost however no separate payment will be made for the erection and dismantling of temporary system includes pipes/valves/tanks/pumps etc. (3). No separate payment will be made for INSTALLATION OF TEMPORARY PIPING
5	Terms of Payment for APH	Terms of payment 1.7.21 to 1.7.29	Progreesive payment against monthly RA Bills for APH will be released as per payment terms 1.7.21 to 1.7.29 in chapter VII in TCC .

SLNO	REF IN TENDER	QUERY	BHEL REPLY
6	1.3.10.2	ELECTRICITY:	<p>BELOW CLAUSES ADDED TO ELECTRICITY (1.3.10.2)</p> <p>1. Necessary "Capacitor Banks" to improve the Power factor as stipulated by customer shall be provided by the contractor at his cost as per customer requirement. Penalty if any levied by customer on this account will be recovered from contractor's bills.</p> <p>2. Any duty, deposit involved in getting the Electricity shall be borne by the bidder. As regards contractor's office shed also all such expenditure shall be borne by the contractor.</p>

**There is no change in other conditions including date of bid submission**

**AGM / Contracts  
BHEL/PSSR**