



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-17-Oct-18

CORRIGENDUM- 07

PROJECT	:	3X800 MW PVUNL PATRATU TPP PHASE-1
PACKAGE	:	CONDENSATE POLISHING UNIT
ENQUIRY NO	:	E-6007/2018 DTD 30/07/2018
SUBJECT	:	PRE-BID CLARIFICATION + DUE DATE EXTENSION

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input checked="" type="checkbox"/>

In reference to the above mentioned tender enquiry for **CONDENSATE POLISHING UNIT** package

Please note the following.

1. Clarification for pre-bid queries are attached for your ready reference.
2. Due date for offer submission has been extended from 17/10/2018 (2:00 pm) to 29/10/2018 (2:00 pm) and P1 shall be opened at 3:00 pm on same day.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Guru Das
Dy. Manager

BHEL's Replies Dtd.16/10/2018 to Pre-Bid Queries (CPU-3X800 MW PATRATU STPP EXT. PH-I)

S.No	Volume	Section	Clause	Page No	Specification requirement	Clarification	BHEL Reply
1	Part 1 of 4 , Volume II -B,	Section C1	D.Valves (viii)	35 of 779	All valves in Service vessel area where pressure may attain same as service vessel shall be designed for 300 lb class minimum.	As per the Tender specifications , Design temperature 70 Deg.c and Design Pressure - 47 Kg/sq.cm , the system requires valves which are more than 300 lb class . As this ,will have a commercial implication and parity with all other bidders ,we request M/S BHEL to confirm the class of valve based on the tender requirement of BHEL.	Specification requirement is clear in this regard.