

**GLOBAL TENDER FOR FUEL OIL HANDLING AND STORAGE SYSTEM OF 2 X 250 MW
NEW NEYVELI TPP (SG)**

Ref No. : PE/PG/NTI/E-4588/2014

Date: 20.10.2014

CORRIGENDUM/ ADDENDUM-1


Our Ref : TENDER ENQUIRY NO: PE/PG/NTI/E-4588/2014 Dt. 10-10-2014
Package : FUEL OIL HANDLING AND STORAGE SYSTEM
Project : 2 X 250 MW NEW NEYVELI TPP (SG)

This is in reference to the above Tender Enquiry No: PE/PG/NTI/E-4588/2014, DTD-10.10.2014 please note that following clarification against above tender enquiry.

SR. NO.	CLAUSE NO.	CLAUSE STATEMENT	Vendor's CLARIFICATION REQUIRED	BHEL REPLY
1	17.0.0 OTHER REQUIREMENTS xi) Page 21 of 303	In case of any contradiction of above specification with that of specification given under section-VIII, the spec. given under section-VIII shall prevail.	Kindly specified the NDT requirement.	Pls read section -VIII as "Annexure-VIII". NDT requirement is mentioned under QAPs, Annexure-VIII etc., which shall be further finalized after award of contract. No further query regarding NDT shall be entertained.
2	Clause 1.1.1 ANNEXURE-I (System Wrtie-Up) Pg 23 of 303	Hose length 8.0 m length with fire safe type ball valve for isolation.	Please clarify the required hose length (i.e 8m or 6m) and the type of isolation valve, whether it's Plug/Ball type.	Hose length shall be 8.0m with ball type valve.
3	Clause 3.4.13.1 Pg 121 of 303	Hose length 6.0 m length long.... One Plug valve isolation valve...		

Thanking You,

With Regards,
For & on behalf of BHEL


Kamal Kishore
Sr. Engineer/PG-II-2

Please reply to:
Kamal K (Engr/PG-II-2)
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)
Tel No. 0120-43638960, 0120-4368730