

Corrigendum-I

Tender Enquiry no. BHE/RU/MNT/2013-14/02 dt:06.07.13

The following modifications has been incorporated vide this corrigendum:

I. Ref: Scope of work(Annexure-II):

Cl. 2: Civil work including digging of earth(2.5 ft deep), laying & connection of cable(cable length **from source of electric supply to High Mast control box** and connectors at source end shall be provided by BHEL) from supply source to high mast shall be in contractor's scope. **Supply of all cables and connectors from High Mast control box to lights etc. shall be in Contractor's scope.**

Cl. 5.: Providing and installation of Lightening arrester with earth spikes alongwith complete earthing system with High Mast Lighting system shall be in contractor's scope. **Proper GI Earthing with two separate earthing pits(one each for lighting arrester and for High Mast) should be provided for each lighting system.**

II. Ref: Notice Inviting Tender

- The sale of tender is extended upto 05.08.13.
- The date of submission of fully completed offer to reach BHEL office extended from 30.07.13 to 06.08.13, 1300 Hrs.
- The date of opening of techno-commercial bids extended from 30.07.13 to 06.08.13

Other scope, terms & conditions, etc. shall remain as per tender enquiry no. BHE/RU/MNT/2013-14/02 dt:06.07.13.