



ISG- BANGALORE

**PROJECT** : CHP & AHP for 2 X 800 MW Yermaras Thermal Power Station, Unit 1 & 2, RPCL- Raichur, Karnataka

**Customer** : M/s Raichur Power Corporation Ltd.



**Work** : Civil & Structural Works  
of Silos

### Clarifications to bidder's query

Tender Enquiry No: 88/14/6012/RSB  
(Package-3)

### Clarifications to bidder's query

Sl.No	Clause No. / (Page No.)	Bidder's Query	BHEL 's Reply
1	Vol.II, Section -D , List of Equipments	30M/hr Batching plant along with transit Mixers are not required for the work. We propose to deploy 2 nos. Mini batchers (Equivalent to RM series of Universal Make).	Agreed. However, Bidder to ensure the casting of raft, shall be completed with-in 22 hrs. Inorder to achieve this, Bidder shall arrange concrete from other sources. Bidder shall also ensure all quality standards as per the requirement of technical specifications. It is also clarified here that this agreement is applicable for package -3 only i.e Civil works of Silo.