

परियोजना  
इंजीनियरिंग  
प्रबंधन

Project Engineering  
Management

भारत हेवी इलेक्ट्रिकल्स लिमिटेड  
(भारत सरकार का उपक्रम )  
**Bharat Heavy Electricals Limited**  
( A Govt. of India Undertaking )



Ref: PE/PG/kar/E-4826/2015/Corrigenda/01

Date: 05<sup>th</sup> June 2015

<b>DUE DATE</b>
<b>25-JUNE-2015</b>
<b>BY 10.00 AM (IST)</b>

**Subject: Change in Technical Specification and Extension of Part-I Bid Opening & Offer Submission Date of HT XLPE CABLES for 3x660 MW North Karanpura STP Project Stage-I**

Our Ref: Open Tender Enquiry No. PE/PG/kar/E-4826/2015 dated 13.05.2015 for HT XLPE CABLES for 3x660 MW NORTH KARANPURA STP Project Stage-I

1. The **due date** for tender submission for subject package is now extended **up to 25<sup>th</sup> JUNE 2015 (10.00 AM IST)**.
2. The **due date** of Part-I (Techno-Commercial) **Bid opening** is now extended up to **25<sup>th</sup> JUNE 2015 (11.30 AM IST)**.
3. **Changes in DATASHEET A Clause No. 7 (b)-ii, 7 (c), 10.0 of Technical Specification No. PE-TS-405-507-E001. Please quote considering the changes in Technical Specification; the same is being uploaded separately.**

Vendors are advised to submit their offer considering the above points.

Vendors who have already submitted their offers are advised to submit revised offers, if they wish to do so, based on above changes. Please note that the last offer submitted before the due date shall be considered for evaluation.

Kindly contact the undersigned in case of any queries.  
Please ensure submission of offer before due date.

Thanking You

With regards  
For & on behalf of BHEL

  
**Manish Kumar Sinha**

Sr. Engineer | PGIII, BHEL PEM | Noida  
E-MAIL: [mksinha@bhlepem.co.in](mailto:mksinha@bhlepem.co.in) | Ph. No. +91-120-4368695, +91 9873414263



कृपया प्रेषित करें : Please reply to : फ़ोन Phone No:  
बीएचइएल, पीएस-पीइएम BHEL, PS-PEM, 91-120 – 436 8500  
पीपीइआई भवन PPEI Building,  
प्लॉट नं २५, सेक्टर १६ ए Plot No.25, Sector 16A,  
नोएडा - २०१ ३०१ उ प्र Noida-201301 (U.P.)  
भारत INDIA

पंजीकृत कार्यालय Registered Office :  
बीएचइएल हाउस BHEL House,  
सीरी फोर्ट Siri Fort,  
नयी दिल्ली – ११० ०४९ New Delhi-110049  
भारत INDIA

**3 X 660 MW North Karanpura TPP**

**HT XLPE POWER CABLES**

**TECHNICAL SPECIFICATION NO. - PE-TS-405-507 -E001**

<b>S.no</b>	<b>Reference Section</b>	<b>Clause No.</b>	<b>Specific Requirement/ Change</b>
1	DATASHEET A	7. (b) - ii	"Wire or tape" shall be read as "wire / tape or combination of both as per IS 7098 part II"
2		7. (c)	"600 A , 2 sec" shall be read as "600 A for 2 sec for each core "
3		10.0	" Innersheath (applicable for all cables except single core unarmoured cable) " shall be read as "Innersheath (applicable for multicore cables)