

परियोजना
इंजीनियरिंग
प्रबंधन
Project Engineering
Management

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
(भारत सरकार का उपक्रम)
Bharat Heavy Electricals Limited
(A Govt. of India Undertaking)



Ref: PE/PG/UNC/E-4558/2014/Corrigenda/01

Date: 26th September 2014

DUE DATE
07-OCTOBER-2014
BY 14.00 PM (IST)

Subject: Clarifications w.r.t. to the technical specification of Mill Reject System for 1x500MW Feroze Gandhi Unchahar TP Stage-IV Project

Our Ref: Open (Global) Tender Enquiry No. PE/PG/UNC/E-4558/2014 dtd. 08.09.2014 for Mill Reject System for 1x500MW Feroze Gandhi Unchahar TP Stage-IV Project

1. The **due date** for tender submission for subject package is now extended **up to 07th OCTOBER 2014 (14.00 PM IST)**.
2. The **due date** for tender opening for subject package is now extended **up to 07th OCTOBER 2014 (15.00 PM IST)**.
3. Clarifications w.r.t. to the technical specification of Mill Reject System (**refer Annexure enclosed**). Please quote considering the clarifications w.r.t. Technical Specification; the same is being uploaded separately. Clarification w.r.t. the Technical Specification to be read along with the Technical Specification given along with NIT.

Vendors are advised to kindly submit your offer considering the above points.

All vendors who have already submitted their offer are required to submit revised offers based upon above changes. Please note that the last offer submitted before the due date shall be considered for evaluation. Kindly contact the undersigned in case of any queries.

Please ensure submission of offer before due date.

Thanking You

With regards
For & on behalf of BHEL

M
26/9/2014
Manish Kumar Sinha

Sr. Engineer | PGIII, BHEL PEM | Noida

E-MAIL: mksinha@bhelpem.co.in | Ph. No. +91-120-4368695, +91 9873414263



कृपया प्रेषित करे :	Please reply to :	फ़ोन Phone No:
बीएचइएल, पीएस-पीइएम	BHEL, PS-PEM,	91-120 - 436 8500
पीपीइआई भवन	PPEI Building,	
प्लॉट नं २५, सेक्टर १६ ए	Plot No.25, Sector 16A,	
नोएडा - २०१ ३०१ उ प्र	Noida-201301 (U.P.)	
भारत	INDIA	

पंजीकृत कार्यालय	Registered Office :
बीएचइएल हाउस	BHEL House,
सीरी फोर्ट	Siri Fort,
नयी दिल्ली - ११० ०४९	New Delhi-110049
भारत	INDIA

1X500 MW UNCHAHAR TPP
Mill Reject Handling System

ANNEXURE

S. No.	Specification Clause	Query	Reply By BHEL
1	Clause No. 03 (e) 2 Volume-IIB page 70 of Section C and 1.1 (e) scope of supply furnished under volume - IIB page 29	The type of valve proposed for maintenance purpose shall be manual operated, however as per the tender flow scheme the type of isolation valve shown at the outlet of pyrite hopper is mentioned as cylinder operated. We understand that the type of isolation valve mentioned in tender flow scheme is typographical error and isolation valve shall be manual operated at the outlet of pyrite hopper, please confirm.	Bidder to follow Clause No. 03 (e) 2 Volume-IIB page 70 of Section C and 1.1 (e) scope of supply furnished under volume - IIB page 29 of technical specification PE-TS-401-160-A001.
2	Clause No. 5 Vol. II B Section C page 70	As per the specified clause Material of construction for filter Bag shall be M.S., IS 2062Gr. A. In this regard we wish to inform you that material of construction of filter bags shall be polyester needle felt type suitable for the application requirement and supplied in all the plants, please confirm	BHEL clarifies that at annexure-II of section C under "Equipment Design/Selection Criteria" S.No.5 "Bag filter" at clause (C) "bag" shall be read as "bag filter body"