

OPEN TENDER FOR STATION LIGHTING SSTEM OF 2X660 MW ENNORE SEZ STPP

Ref No. : E-4882/2015/CORRIGENDUM/06

Date: 29.07.2015

CORRIGENDUM/ ADDENDUM-6

Subject: Corrigenda to Technical specification no. PE-TS-412-507-E001

Ref: Our Tender Enquiry No. E-4882/2015 dated 05.06.2015 for STATION LIGHTING SYSTEM for 2X660MW ENNORE SEZ STPP

This is in reference to the subject Tender Enquiry please note the following Technical clarifications:-

1. In BOQ cum price schedule Annexure-1 sl no 14.0 description to be corrected to flexible conduit electro-galvanized and PVC coated for both inside and outside.
2. In BOQ cum price schedule Annexure-1 sl no 14.1 description to be corrected to 20mm dia flexible conduit electro-galvanized PVC coated for both inside and outside.
3. In BOQ cum price schedule Annexure-2 sl no 12.0 description to be corrected to flexible conduit electro-galvanized and PVC coated for both inside and outside.
4. In BOQ cum price schedule Annexure-2 sl no 12.1 description to be corrected to 20mm dia flexible conduit electro-galvanized PVC coated for both inside and outside.

Thanking You,

With Regards,

For & on behalf of BHEL

Rajeev Kumar

Sr.Engineer/PG-II-2

Please reply to:
Rajeev Kumar (Sr.Engr/PG-II-2)
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)
Tel No. 0120-4213582