



**BHARAT HEAVY ELECTRICALS LIMITED**  
**PROJECT ENGINEERING MANAGEMENT**

**PROJECT : 1X800 MW TSGENCO KOTHAGUDAM TPP**  
**PACKAGE : EFFLUENT TREATMENT PLANT**

**DATE: - 22.03.2016**

**Corrigenda/Addenda-7**

Reference: i) Enquiry No. PE/PG/KG1/ E-5134/2015 Dtd. 18.12.2015  
ii) Corrigenda/Addenda-1 Dtd. 13.01.2016  
iii) Corrigenda/Addenda-2 Dtd. 27.01.2016  
iv) Corrigenda/Addenda-3 Dtd. 09.02.2016  
v) Corrigenda/Addenda-4 Dtd. 16.02.2016  
vi) Corrigenda/Addenda-5 Dtd. 07.03.2016  
vii) Corrigenda/Addenda-6 Dtd. 14.03.2016

**Due Date : 05/04/2016 (02:00 PM)**

**Subject: Due date Extension and Amendment-3 in Technical Specification**

- 1). Bid submission date against Tender Enquiry PE/PG/KG1/E-5134/2015 Dated 18.12.2015 is extended till **05.04.2016 (02.00 PM)**. The Techno-Commercial Bids shall be opened same day at **03.00 PM**.
- 2). Amendment-3 is being issued due to change in Technical Specification. Amendment details are enclosed herewith.

Bidders are requested to submit the revised offer (if applicable) before due date & time.

All other terms and conditions shall remain unchanged.

Regards

Rajeev Kumar

Sr. Engineer

PG-II-2



**AMENDMENT ON TECHNICAL SPECIFICATION  
FOR EFFLUENT TREATMENT PLANT**

**1X800 MW TSGENCO KOTHAGUDEM TPS  
STAGE –VII, PALONCHA**

SPECIFICATION NO.: PE-TS-410-164-A001 REV 01  
AMENDMENT NO # 3

REV. NO. 00

DATE: 21/03/2016

Page 1 of 1

The following modifications with respect to Technical Specification for **EFFLUENT TREATMENT PLANT**, BHEL's Technical specification no PE-TS-410-164-A001 REV 01 shall apply.

**MODIFIED CLAUSES/PAGE NUMBERS.**

Sl no.	Vol. No.	Section/Description	Clause no	Page no	Existing	Modified to
1.	IIB	SECTION C3	26	Page 124 of 592	SPECIFIC TECHNICAL REQUIREMENTS C&I- New clause Added.	In addition to the items as indicated in technical specification the below mentioned items shall also be in Bidder scope:  26. Minimum Four (4) numbers RIO panels and 3 KM fiber optic cable with redundant communication type is in Bidder's scope of supply. Location of Remote IO panel shall be in line with Technical specification.
2.	IIB	SECTION C1	--	Page 111 of 592	P&ID FOR EFFLUENT TREATMENT PLANT- CCTV CAMERA AT CLEAR WATER RESERVOIR	The CCTV camera at Clear Water Reservoir is excluded from Vendor's scope of supply.

\*\*\*\*\*