



**OPEN TENDER ENQUIRY FOR MISC PUMP (HORIZONTAL) FOR 1X 800 MW GSECL
WANAKBORI STPP UNIT 8**

Ref No. : PE/PG/WAN/E-5156/2015

Date: 20.02.2016

CORRIGENDUM/ ADDENDUM- 4

Tender Enquiry no.: PE/PG/WAN/E-5156/2015
Date: 12.01.2016

Extended DUE DATE
29 FEB 2016
10:00 AM

Sir/Madam,

Please find attached the reply of Pre-Bid query asked by bidders along with this corrigendum.

All bidders are requested to visit BHEL websites www.bhel.com (Tender Notifications Section)
OR www.bhelpem.com (http://www.bhelpem.com/Tenders_Rev/NewTenders.aspx), all future
corrigendum, addendums, amendments, if any, for this tender shall be hosted only on above
websites

Please ensure submission of your offer on or before extended due date & time.

Thanking you,

Yours faithfully,
For and on behalf of BHEL

**SHRI
PRAKASH
YADAV**

Digitally signed by SHRI PRAKASH
YADAV
DN: c=IN, o=BHARAT HEAVY
ELECTRICALS LIMITED, ou=SENIOR
ENGINEER, postalCode=201301,
st=Uttar Pradesh,
2.5.4.20=8f4e11ceddc03ac5af370373
2a80511e95fb3b8614e26b64a18d90c
3591aad3, cn=SHRI PRAKASH YADAV
Date: 2016.02.20 12:50:26 +05'30'

SHRI PRAKASH YADAV
(Sr.ENGINEER/Project Group-1-1)

Please reply to:

**SHRI PRAKASH YADAV-SR.ENGR
PGI-I**

Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)
Tel No. 0120-4213621

Project Name : 1X800 MW GSECL,Wanakbori STPP, Unit -8

Package Name : MISC PUMP (HORIZONTAL)

Enquiry No: PE/PG/WAN/E-5156/2016 Dtd. 12.01.2016
Due Date: 29.02.2016

Sl No:	Bidder's Pre-Bid Query	BHEL's Reply
1	<p>You are requested to clarify the followings points</p> <p>1. kindly note that the we have considered IE-3 motors, considering the technical specification for the motors (point no-2.02.00 of EPC bid document K9213R-EPC-SPC-001.</p> <p>2. AS per IS-12615 the staring current for IE-3 motors varies from minimum 700 % to 770 % of full load current subject to IS tolerance of 20 % where as the specification of motors in EPC bid document K9213R-EPC-SPC-001 limit the starting current to 720 % of full load current including all tolerance.</p> <p>Kindly clarify the above point.</p>	<p>Starting current shall be as per customer specification EPC bid document K9213R-EPC-SPC-001.</p>
2	<p>We observed that multiple filed is there for same items in the price bid (mandatory spares) so please clarify the same</p>	<p>Bidder query is not clear. Bidder may give the specific query 'multiple filed is there for same items'.</p> <p>However as far as mechanical seal appearing at two points for few pumps is concerned, same is done intentionally as per customer's list of mandatory spares.</p>