



Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)

**Project Engineering
Management**

**OPEN TENDER ENQUIRY FOR CONDENSATE POLISHING UNIT FOR 1X 800 MW
GSECL WANAKBORI STPP UNIT 8**

Ref No. : PE/PG/WAN/E-5064/2015

Date: 23.12.2015

CORRIGENDUM/ ADDENDUM- 6

Tender Enquiry no.: PE/PG/WAN/E-5064/2015
Date: 15.10.2015,

EXTENDED DUE DATE
24 Dec 2015
02:00 PM

Sir,

Please find attached the reply of Pre-Bid query asked by bidders along with this corrigendum.

All bidders are requested to visit BHEL websites www.bhel.com (Tender Notifications Section) OR www.bhelpem.com (http://www.bhelpem.com/Tenders_Rev/NewTenders.aspx), all future corrigendum, addendums, amendments, if any, for this tender shall be hosted only on above websites

Thanking you,

Yours faithfully,
For and on behalf of BHEL

**RAHUL
BHATNAGAR**

Digitally signed by RAHUL BHATNAGAR
DN: c=IN, o=BHARAT HEAVY ELECTRICALS LIMITED,
ou=SENIOR ENGINEER, postalCode=201301, st=Uttar
Pradesh,
2.5.4.20=703d3aa622c7131917d638e0e171c8e24d05e
d3a30bf0bbe8f85cdb52527529f, cn=RAHUL
BHATNAGAR
Date: 2015.12.23 17:21:46 +05'30'

**RAHUL BHATNAGAR
(Sr.ENGINEER/Project Group-1-1)**

Please reply to:

**Rahul Bhatnagar-Sr.Engr. / Rajeev Ranjan, Asst. Engineer
PGI-I**

Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)
Tel No. 0120-4368727/4368838

Project: Condensate Polishing Unit as per Tech. Spec. No.PE-TS-408-155-A001 Rev 00 for 1 × 800 MW GSECL Wanakbori TPP, Unit - 8.

Owner: Gujarat State Electricity Corporation Limited (GSECL)

Client: Bharat Heavy Electricals Limited

Enquiry No.: PE/PG/WAN/E-5064/2015 dated October 15, 2015

Doc. Title: Pre-Bid Queries -

Sr. No.	Volume	Section	Clause No.	Page No.	As per tender	Clarification required	BHEL Reply
1	SCC- Rev 01		19 (i)	3 of 6	Concessional basic customs duty @ 5% (Project Under PI route) , CVD & SAD (as per prevailing rates) shall be applicable for packages for which CIF content is available as per NIT and Customer shall arrange Essentiality certificate for availing concessional customs duty benefits. Statutory variation in the rate of imports under project import benefits along with corresponding implications of taxes and duties thereon the total CIF value shall be entertained within scheduled delivery time frame of the purchase order.	Whether CENVAT benefit shall be availed when the goods are dispatched from our Factory?	Referred Tender Clause is regarding Imports. Regarding availing of CENVAT benefit in lieu of E.D. applicable on inputs is totally governed by existing Laws and no restrictions have been mentioned in the Tender till the time it does not have any implications to BHEL
2	SCC- Rev 01		19 (ii)	4 of 6	Excise duty - Vendor to quote excise duty at applicable rate & amount on self manufactured items and same shall be considered for evaluation .Excise duty is payable on self manufactured items only.	Whether CENVAT benefit shall be availed when the goods are dispatched from our Factory?	Refer above reply at Sr. No. 1.
3	II - B	C1	I.Salient Design Data ,(a)Normal run	43 of 701	Design Analysis of crude condensate during normal run	Since, individual analysis is provided, TDS shall be considered based on individual load.	Please follow technical specification.
4	II - B	C1	I.Salient Design Data ,(b) Startup condition	44 of 701	Design Analysis of crude condensate during Startup condition	Since, individual analysis is provided, TDS shall be considered based on individual load.	Please follow technical specification.
5	II - B	C1	Data sheet , Cl.no-3.2 ,Point No-(v) - Useful capacity	57 of 701	Hydrochloric acid Storage tank - Adequate to hold the quantity of commercial acid required for thirty (30) days of operation.	Kindly confirm whether the quantity of acid for 30 days of operation shall be for single vessel or all the three vessels.	Bidder to note that the capacity of Hydrochloric acid Storage tank will be adequate to hold the quantity of commercial acid required for thirty (30) days of operation for all the three condensate polisher service vessels. Bidder to please follow technical specification.
6	II - B	C2	Data sheet , Cl.no-3.3, Point No-(v) - Useful capacity	58 of 701	Alkali Storage tank - Adequate to hold the quantity of commercial acid required for thirty (30) days of operation.	Kindly confirm whether the quantity of acid for 30 days of operation shall be for single vessel or all the three vessels.	Bidder to note that the capacity of Alkali Storage tank will be adequate to hold the quantity of commercial alkali required for thirty (30) days of operation for all the three condensate polisher service vessels. Bidder to please follow technical specification.