



ISO 9001-2000, ISO 14001, OHSAS 18001  
and SA 8000 certified company  
Sub-Contract and Purchase Department.

# भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

**BHARAT HEAVY ELECTRICALS LIMITED**

(A Govt. of India Undertaking)

पावर सेक्टर, उ.क्षे.परिसर, प्लाट नं.25, सेक्टर-16ए, पोस्ट बॉक्स सं.55, नोएडा-201301,  
Power Sector-Northern Region, Plot no.25, Sector 16 A PB NO. 55, NOIDA. 201301

Ph : 0120-2416548 / 2416262 , Fax 0120-2515464

e-mail: [rahuldeb@bhel.com](mailto:rahuldeb@bhel.com), [susmitbasu@bhel.com](mailto:susmitbasu@bhel.com)

## CORRIGENDUM-I

13.01.2014

**Ref.:** Tender No: **BHEL/PSNR/SCP/RD/E-2629 DATED 09.01.2015**

**Sub.:** **Modification in Tender Enquiry No.** BHEL/PSNR/SCP/RD/E-2629 DATED 09.01.2015  
for the supply & Commissioning of 01 Nos. of 3.3 MVA Single Phase Core Flux Test  
Set with all accessories.

Dear Sir,

Kindly be informed about the following points regarding above tender:

- 1) In item –A of **Annexure-1** of NIT, Page 3 of 24, sub-para(b) under “Other Features”  
it was mentioned as:  
“The transformer shall be equipped with **Air Breather Type Breaker** for input supply  
with standard protection features.”  
**This has been modified and may be read as –**  
“The transformer shall be equipped with **VCB Type Circuit Breaker** for input supply  
with standard protection features.”
- 2) All other terms and condition of the tender shall remain unchanged.
- 3) This corrigendum shall be part of the tender

The Techno-Commercial bid shall be opened on 30.01.2014 at **15:30 Hrs.** and Offer to be  
submitted latest by 30.01.2014 **15:00 Hrs.** You may depute your authorized representative  
to witness the event.

Thanking You,

Yours faithfully  
For and on behalf of BHEL

Engineer/Purchase.