



# Bharat Heavy Electricals Limited

(High Pressure Boiler Plant)

Tiruchirappalli – 620014, TAMIL NADU, INDIA

MATERIALS MANAGEMENT / CAPITAL EQUIPMENT

An ISO 9001 Company

<b>Corrigendum 1</b>	Phone: +91 431 257 7653 Fax : +91 431 252 0719 Email :skaruna@bheltry.co.in Web : <a href="http://www.bhel.com">www.bhel.com</a>
----------------------	---


<b>NIT No. 24062</b>	<b>Enquiry Number:</b> 2631500005	<b>Enquiry Date:</b> 22.08.2015	<b>Due date for submission of quotation extended to:</b> 26.09.2015
----------------------	--------------------------------------	------------------------------------	--

You are requested to quote the Enquiry number, date and due date in all your correspondences. This is only a request for quotation and not an order.  
Please note that under any circumstances both delayed offer and late offers will not be considered. Hence vendors are requested to ensure that the offer is reaching physically our office before 14.00 hrs on the Date of tender opening.

**Item Description: Kitchen Exhaust and Fresh Air Ventilation System – 1 set**

<b>Details of Corrigendum</b>
1) <i>Changes in the technical specification as per the annexure.</i>
2) <i>Due Date extended upto 26.09.2015.</i>
All other terms and conditions and specifications as published in the NIT No. <b>24062</b> remains unaltered.

Confirmation of acceptance for BHEL commercial terms & conditions and Price Bid formats have been posted in BHEL Corporate web site [ww.bhel.com](http://www.bhel.com) or from the Government tender website <http://tenders.gov.in> (public sector units > Bharat Heavy Electricals Limited page) under Enquiry reference "2631500005".


Tenders should reach us before 14:00 hours on the due date Tenders will be opened at 14:30 hours on the due date Tenders would be opened in presence of the tenderers who have submitted their offers and who may like to be present	Yours faithfully, For BHARAT HEAVY ELECTRICALS LIMITED  <b>KUMAR GAUTAM SINGH</b> Senior Engineer MM / Capital Equipment BHEL, TRICHY - 620 014.
--	--

## CORRIGENDUM

Ref Open Tender No: 2631500005 dt: 22.08.15

Item description: Kitchen Exhaust and Fresh Air Ventilation System - 58 Canteen

S.No	Clause No.	Existing specification	Revised specification
1	4.6	Impellor material construction - Mild Steel Powder Coated	Impellor material construction - Mild Steel, Epoxy painted
2	4.7	Casing material - Mild steel Powder Coated	Casing material - Mild steel, Epoxy painted
3	6	Hoods	Hoods: Individual hoods to be provided separately for the 5 dosa plates. The dimension (L x W) of the hood should be bigger than the dosa plates by atleast 6 inches.
4	8.2	Thickness not less than 22G for main duct and 24G for bends	Thickness not less than 22G for main duct and 22G for bends
5	10.6	Impeller material construction - Mild Steel Powder Coated	Impeller material construction - Mild Steel, Epoxy painted
6	10.7	Casing material - Mild steel Powder Coated	Casing material - Mild steel, Epoxy painted
7	15.2	Thickness not less than 22G for main duct and 24G for bends	Thickness not less than 22G for main duct and 22G for bends
8	18.4	Impeller material construction - Mild Steel powder coated	Impeller material construction - Aluminium

  
**P. ELANGO**  
Maintenance Engineer  
Maintenance & Services  
BHEL, TRICHY - 620 014.


  
**AR. SOLAIRAJ**  
Sr. Engineer  
Maintenance & Services  
BHEL, TRICHY - 620 014.

  
**S. SELLADURAI**  
Dy. General Manager  
Maintenance & Services  
BHEL, TRICHY - 620 014.

9	18.7	Casing material - Mild steel powder coated	Casing material - Mild steel, Epoxy painted
10	23.2	Thickness not less than 22G for main duct and 24G for bends	Thickness not less than 22G for main duct and 22G for bends
11	25.4	Impellor material construction - Mild Steel powder coated	Impellor material construction - Aluminium
12	25.7	Casing material - Mild steel powder coated	Casing material - Mild steel, Epoxy painted
13	32.2	Thickness not less than 22G for main duct and 24G for bends	Thickness not less than 22G for main duct and 22G for bends
14	Note - Sl.No: 10	The Exhaust and Fresh air blowers are to be installed on the terrace of the 58 Canteen	The Exhaust and Fresh air blowers are to be installed on the ground area adjacent to Bldg.58 Canteen. Blower mounting base frames along with suitable foundation bolts and nuts to be supplied by the vendor. Civil foundation will be provided by M/s BHEL.The height of the exhaust chimneys to be maintained atleast 1.5 m above the terrace level. Vendors should furnish the scope of work like civil concrete foundation, structural design details etc. well in advance with details.

  
**P. ELANGO**  
 Maintenance Engineer  
 Maintenance & Services  
 BHEL, TRICHY - 620 014.

  
**R. SOLAIRAJ**  
 Sr. Engineer  
 Maintenance & Services  
 BHEL, TRICHY - 620 014.

  
**S. SELLADURAI**  
 Dy. General Manager  
 Maintenance & Services  
 BHEL, TRICHY - 620 014.