

BHEL PSSR SCT DEPT
CORRIGENDUM -1 TO TENDER NOTICE BHEL PSSR SCT 1489,dated:1/2/2012

Some of the bidders sought clarifications vide letters or in Pre Bid discussion held on 30.01.2012 at BHEL PSSR Regarding Yermarus 2x800MW Civil and Structural Works Tender Specification BHEL PSSR SCT 1489 and clarifications are furnished below for your information

S.No	Ref	Bidder's Query	BHEL Reply
1		BOQ 913 C:Rolling shutter: Please confirm whether our cost price includes the cost of motor, if so, whether Indian or foreign make shall be provided (.)	BOQ item is clear, bidder to quote accordingly
2		BOQ-920: Roof sky light: We presume that the supporting structure/grid shall be measured and paid seperately	Suppoting structures will be measured and paid as per the applicable item.
3		BOQ-1003: Brick partition: We presume that the reinforcement steel shall be measured and paid seperately vide Item No. 406	yes
4		BOQ- 1005: Brick soiling: Please confirm the thickness to be provided	Soiling thickness shall be same as brick thickness on edge.

S.No	Ref	Bidder's Query	BHEL Reply
5		BOQ- 1401: Cement flooring: We presume the glass strips shall be measured and paid seperately vide Item No. 1430	BOQ item is clear, bidder to quote accordingly.Paid as per 1401 only.
6		BOQ 1412: Granite: Please mention the type of granite	Blue and black type granite
7		BOQ- 2002: Provide the total height of fencing (3.0m ?)	BOQ item is clear, bidder to quote accordingly
8		BOQ-2300: BHEL free issue, loading, transporting and unloading from BHEL stores to location shall be done by bidder: We presume that it is structural steel and not reinforcement steel	To be read as: "BHELwill supply structural steel as a free issue, loading, transporting and unloading from BHEL stores to location shall be done by bidder"
9		Boq Item No. 2307-Please clarify whether the supply of electroforged Gratings in BHEL scope	Supply is under bidder's scope
10		BOQ 2307, 2310, 2311: Structural steel: we presume our pricde includes cost of material	in BOQ item 2307, 2310, 2311 supply is in bidder's scope
11		BOQ A2414: RCC hume pipe: We presume that the trenching/backfilling shall be measured and paid seperately	Yes .Will be measured and paid as per the applicable item
12		BOQ 2426: Paver block: Please provide the grade of concrete	M30 Grade of concrete shall be used.
13	BOQ 108	Back filling: Transportation of selected materials directly from excavation for backfilling will be paid under relevant items of excavation.please confirm	As per tender conditions only
14	BOQ 218	Cutting Reinforced concrete:Please specify maximum depth of cutting of Reinforced concrete with core drilling machine	BOQ Items is clear, bidder to quote accordingly.item will be measured in CUM.
15	BOQ 1205& 1206	Plaster: Please provide the ratio of cement mortar	Cement mortar 1:6 shall be adopted
16	ST no. 1708	Pl. specify the pressure rating for HDPE downtake pipes	Min. pressure rating for HDPE downtake pipe is PN 6 as per IS 4984:1995.

S.No	Ref	Bidder's Query	BHEL Reply
17	ST no. 1810	Pl. provide the details of rail	Railof weight will be 52Kg/M
18	ST No. 1817	Pl. specify the pressure rating for HDPE pipes	Min. pressure rating for HDPE downtake pipe is PN 6 as per IS 4984:1995.
19	ST no. 2208 & 2209	RCC pipes: necessary excavation, bad concrete, backfilling etc will be measured and paid under relevant items of BOQ - pl confirm	Yes
20	ST no. 2414A	Hume pipes: necessary excavation, bad concrete, backfilling etc will be measured and paid under relevant items of BOQ - pl confirm	Yes
21	ST no. 2426 & 2427	Pl specify the grade of concrete required for precast interlocking concrete pavers.	M30 Grade of concrete shall be used.

All other conditions and tender submission date remain same

AGM/Contracts