

Ref: BHE/PW/PUR/BSI1-CVL/1109/Corrigendum 01

Date 11/02/2013

-----Page 1 of 2-----

To

ALL BIDDERS

Sub: Corrigendum -01 for Issue of Clarifications and Time Extension

Job: CONSTRUCTION OF RCC FOUNDATIONS FOR STEAM TURBINE WITH TURBO BLOWER (EXCEPT BOTTOM RAFT) AND ITS AUXILIARIES, AIR INLET FILTERS, MISCELLANEOUS EQUIPMENT FOUNDATIONS, PIPE RACK , PLATFORMS, PAVING AND ASSOCIATED STRUCTURAL WORKS FOR TWO UNITS (UNIT 2&3) AT 3 X18 MW TURBO BLOWER STATION, SAIL-BHILAI, DIST: DURG, CHHATISGARH.

Tender Specification Number: BHE/PW/PUR/BSI1-CVL/1109

Bidders to kindly take note of the following:

=====

AA) Clarification to the Queries of Bidder

SI No.	Reference Clause	Bidder's query	BHEL's clarification
1	Vol-II Price bid item 209	(i) Please Give complete specification for materials and workmanship, ambient temperature at which concrete is to be poured for ensuring of concreting at below 23 ⁰ C. (ii) Please specify method to be adopted and the end result.	There is no specification for cooling concrete & temperature of fresh concrete is to be maintained/controlled by adding ice in water during mixing and sprinkling cold water on aggregate. The time of pouring of concrete to be decided mutually at site suitably to avoid day time max. Temperature due to hot scorching Sun during summer. Since the quantity is very less, it can be planned suitably at site.
2	Vol-II Price bid item 213	(i) Please state that height of the roof and the profile of the pre cast slab. (ii) Please clarify whether reinforcement and / or steel inserts are to be used.	(i) There is no building in the scope of contract Ref. Chapter-II, Scope of wok. Hence there is no precast slab over the roof. All precast slab shall be at GL for covering the pipe trench/ cable trench and it is flat of rectangular shape. (ii) The reinforcement and other steel part if any shall only be paid separately under relevant item – 400 & 700
3	Vol-II Price bid item 705	(i) Please give specification and range of dia of M.S pipe inserts. (ii) Please give range of dia of PVC pipes (iii) Please give range of dia of UPVC pipe conduits. Normally, the unit of measurement is RM. Please provide the same.	The range of dia. of PVC, UPVC and MS pipe shall be – 100mm to 250mm. The Unit of measurement shall be as per BOQ (in Quintal only). Bidders are requested to quote accordingly.

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
पावर सेक्टर- पश्चिमी क्षेत्र
श्रीमोहिनी कॉम्प्लेक्स, 345 - किंग्सवे
नागपुर- 440 001



Bharat Heavy Electricals Limited
Power Sector-Western Region
Shreemohini complex, 345 - Kingsway
Nagpur -440 001

फोन / Phone 0712- 3048600 TO 604 फैक्स FAX: 0712- 3048698- 699/ 3048605 www.bhel.com

Ref: BHE/PW/PUR/BSI1-CVL/1109/Corrigendum 01

Date 11/02/2013

-----Page 2 of 2-----

BB) EXTENSION of LAST DATE:

The last date for submission of Tender has been re scheduled to 13/02/2013, 15.00 hrs.

Technical Bid shall be opened on 13/02/2013 at 16.00 hrs

=====
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-01 (Clarification-1109)" against NIT-13600 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)