

Ref: BHE/PW/PUR/DHJOI-CNI/1033/Corrigendum 01

Date 21/08/2012

-----Page 1 of 2-----

To

ALL BIDDERS

Sub: Corrigendum -01 for Issue of Clarifications

JOB: HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, CHECKING OF CALIBRATION, TESTING, COMMISSIONING AND HANDING OVER OF CONTROL & INSTRUMENTATION WORKS FOR UTILITY BOILER AND ITS AUXILIARIES, HRSG AND ITS AUXILIARIES, STEAM TURBINE AND ITS AUXILIARIES, GAS TURBINE AND ITS AUXILIARIES, TURBOGENERATOR AND ITS AUXILIARIES, STATION C&I FOR **2x30MW STG+4xFr6B GTG OPAL DAHEJ PROJECT AT ONGC PETRO ADDITIONS LIMITED (OPAL) DAHEJ, SEZ NEAR VILLAGE AMBHETHA AT DAHEJ, DISTRICT-BHARUCH.**

Tender Specification Number: BHE/PW/PUR/DHJOI-CNI/1033

Bidders to kindly take note of the following:

=====

AA) Clarification to the Queries of Bidder

Sl No.	Reference Clause	Bidder's query	BHEL's clarification
1	Volume II, SOR Sr,Bi,I2.0.31	We presume that FO cable termination work is excluded from our scope of work. Kindly confirm.	Termination will be done by FO cable vendor
2	Vol. I TCC, clause No.2.11.0	The System comprises of weldable pads to be welded on SS block on HT motors end shield and fan bearing housing. Generally, equipments are coming along with the pads or if it is required to be welded at site then the same shall be carried out by other agency. Kindly confirm.	Weldable SS blocks are to be welded by the bidder.
3	Voll, NIT, page No.6 of 106, Sr.No.V	We are planning to visit site on 21st August '12 to understand the site environment. Request you to kindly intimate Site Construction Manager to arrange the Visitors gate pass for us. Considering the volume of work and reasonable time required for preparation of details for tender, we request you to extend the Tender Submission date suitably.	Due date of offer submission can not be extended

=====

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
पावर सेक्टर- पश्चिमी क्षेत्र
श्रीमोहिनी कॉम्प्लेक्स, 345 - किंग्सवे
नागपुर- 440 001



Bharat Heavy Electricals Limited
Power Sector-Western Region
Shreemohini complex, 345 - Kingsway
Nagpur -440 001

फोन / Phone 0712- 3048600 TO 604 फैक्स FAX: 0712- 3048698- 699/ 3048605 www.bhel.com

Ref: BHE/PW/PUR/DHJOI-CNI/1033/Corrigendum 01

Date 21/08/2012

-----Page 2 of 2-----

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-01 (Clarification-1033)" against NIT-12500 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)