

To
ALL BIDDERS

Sub: Corrigendum -01 for Issue of Clarifications and Time Extension

JOB: COLLECTION OF MATERIALS FROM BHEL/CLIENT'S STORES/STORAGE YARD; TRANSPORTATION TO SITE; ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF BOILER AND ITS AUXILIARIES, AIR PREHEATERS, DUCTS AND DAMPERS, FUEL PIPING, BOILER INTEGRAL PIPING, ELECTROSTATIC PRECIPITATOR, FANS, POWER CYCLE PIPING, COAL MILLS AND COAL FEEDERS, CHEMICAL DOZING SYSTEM, INSULATION, FINAL PAINTING (INCLUDING SUPPLY) ETC AT UNIT-13 OF 1X500 MW NTPC VINDHYACHAL PROJECT NEAR VINDHYANAGAR DISTRICT SINGRAULI IN MADHYA PRADESH STATE

Tender Specification Number : BHE/PW/PUR/VNT5-BLR(Vertical Pkg)U13/1091

Bidders to kindly take note of the following:

=====

AA) Clarification to the Queries of Bidder

SI No.	Reference Clause	Bidder's query	BHEL's clarification
1	Sr. No. 7 at page no. 31 & Cl. no. 6.1.2 at page 46 of Vol IA 'TCC'	As per Sr. No.7 Pre-commissioning/ commissioning are in contractor scope and as per Cl No 6.1.2 on page 46 only assistance during commissioning is to be provided by contractor. Please Clarify.	Commissioning is in BHEL scope. However contractor has to assist during commissioning activities as per instruction of BHEL engineer.
2	Cl. No. 4 at page 31 of Vol IA 'TCC'	As per tender Transportation/dragging of boiler drum from unloading bay is in contractor scope. Please confirm the approximate distance from Drum unloading bay to boiler structure	Approximate distance from unloading bay of Boiler drum to inside boiler structure is 150 mtr.
3	Cl. No. 3.1.2 (a) at page 32, Cl. No. 3.2.1 at page 33 and Cl. No. 3.2.3 at page 34 of Vol I A TCC– facilities in the scope of contractor / BHEL of TCC	As per tender, Open space for labour colony and power connection for construction is to be provided by BHEL free of cost whereas the power connection for labour / staff colony is to be arranged by contractor. Please confirm that power connection for labour and staff colony shall also to be provided by BHEL on chargeable basis.	Contractor has to make his own arrangement for power connection for labour and staff colony. However if Customer provides power supply for labour & staff colony to BHEL, same shall be provided to contractor at same terms & conditions (at prevailing rates at site).
4	Sr. No. 32 on page 41 of Vol IA 'TCC' – List of T&P to be deployed by contractor	One each HT Pump of 600, & 450 Kg per cm sq. is required as per tender. Please confirm if two pumps are required or only one is sufficient.	Tender Condition holds good. Both pumps are required as per tender.
5	Cl. 3.2.1 (a) at page 33 of Vol IA TCC – facilities in the scope of contractor / BHEL	As per tender Single point power connection shall be provided by BHEL at a distance of 700 meter from site. Laying of cable for power connection for a distance of 700 meter, voltage drop shall be very high for 440 Volt supply and also for such a distance there will be chances of damaging of cable by other agency shall be very high. You may allow us to lay overhead lines for such a distance. Pl. confirm	Construction power shall be taken through shortest possible distance. The distance of 700 mtr is approximate and may vary as per site conditions. Overhead lines are not permitted
6	Sr. No. 8 at page 31 of Vol IA TCC	As per painting schedule given on page 86 of TCC there is no mention of	In case intermediate paint is not applicable as per painting schedule,

SI No.	Reference Clause	Bidder's query	BHEL's clarification
	'Supply of primer / intermediate /finish paint and final paint of erected item is in the scope of sub-contractor'	intermediate paint also we feel that finish or final paint is the same thing. Please clarify.	same will not be applied. Finish & final paint are same.
7	Sr No. 2 & 3 at page 45 of vol IA 'TCC' – T&P's to be deployed by BHEL	As per tender Crane Operator for BHEL owned crane / hiring basis will be provided by BHEL / hire agency. Please confirm that operator is provided free of cost or on chargeable basis	Operator will be provided free of cost for BHEL owned/hired crane.
8	Clause No. 11.9 at page128 and Clause. No. 17.15 at page 161 of Vol IA TCC	As per Cl. 11.9 The contractor shall perform work with in quoted rates And as per cl. 17.15 - Contractor shall carry out perform by contractor Since BHEL is the manufacturer, pl. let us know the range / kind of services / tests required.	Contractor has to perform tests like EDTA Cleaning, steam blowing, air leak test of ESP, Kerosene test of duct, other tests during pre-commissioning & commissioning activities etc. which will be related with equipment erected under scope of contract by Contractor.
9	Cl. No. 4.2.2.9 on page 12 of Vol IC 'SCC'	As per clause 'the area and infrastructure development Shall be responsibility of contractor' Pl, confirm the approx. area which the contractor has to back fill & consolidate so that proper costing could be done.	Enabling work (development of material yard/sheds) is in BHEL scope. However during execution of contract, if back filling & consolidation is required, it will be limited only for smooth execution of mentioned work as per contract near Boiler & ESP area.
10	Cl. No. 4.1.4 at page 7 of Vol IC 'SCC'	Title of Clause No 4.1.4 of Volume IC' SCC' may be read as: "TIG Filler Wire for Boiler and Filler wires and Electrodes for P-91/T-91 Piping"	

BB) EXTENSION of LAST DATE:

The last date for submission of Tender has been re scheduled to 07/02/2013, 15.00 hrs.

Technical Bid shall be opened on 07/02/2013 at 16.00 hrs

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-01 (Clarification-1091)" against NIT-13461 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,
AGM (Purchase)