

Ref: BHE/PW/PUR/DHJOI-BLR/966-967/Corrigendum 02

Date 01/03/2012

-----Page 1 of 2-----

To
ALL BIDDERS

Sub: Corrigendum -02 for Issue of Clarifications

JOB: RECEIPT/COLLECTION/LOADING/UNLOADING/TRANSPORTATION OF MATERIALS FROM BHEL/CLIENT'S STORES/STORAGE YARD TO SITE OF WORK, ERECTION, TESTING, COMMISSIONING, SUPPLY OF PAINTS/PRIMER AND APPLICATION OF PAINTS FOR FINAL PAINTING AND HANDING OVER OF 220 TPH UTILITY BOILER (UB) + 110 TPH HEAT RECOVERY STEAM GENERATORS (HRSG) ALONG WITH ITS AUXILIARIES, STEEL STACK WITH COMPLETE PLATFORMS ETC INCLUDING ELECTRICAL WORK OF STACK, PIPING (POWER CYCLE PIPING, INTEGRAL PIPING, CONDENSATE & FEED WATER PIPING, DM WATER, HSD & NAPHTHA PIPING, NATURAL GAS, COOLING WATER, REGENERATIVE CYCLE PIPING, INCLUDING PLANT AIR, INSTRUMENT AIR & SERVICE AIR PIPING ETC.) WITH ASSOCIATED FITTINGS, VALVES, HANGERS & SUPPORTS, APPLICATION OF THERMAL INSULATION OF UB AND HRSG WITH AUXILIARIES, STEEL STACK, PIPING WITH VALVES & FITTINGS INCLUDING GAS TURBINE AND STEAM TURBINE SET EQUIPMENTS – HEATERS, DE-AERATOR, TANKS, VESSELS & PIPING ETC FOR OPAL (ONGC PETRO ADDITIONS LIMITED) STEAM AND POWER GENERATION SYSTEM PACKAGE FOR DAHEJ PETROCHEMICAL COMPLEX, SPLIT AS (Block I) UTILITY BOILER 1, HRSG 2 AND 4, (Block II) UTILITY BOILER 2, HRSG 1 AND 3.

SI No	Tender Specification Number	Unit Number & Project
1	BHE/PW/PUR/ DHJOI-BLR (BLOCK-I)/966	UTILITY BOILER 1, HRSG 2 AND 4 (Block I)
2	BHE/PW/PUR/ DHJOI-BLR (BLOCK-II)/967	UTILITY BOILER 2, HRSG 1 AND 3 (Block II)

Bidders to kindly take note of the following:

=====

AA) Clarification to the Queries of Bidder

SI No.	Reference Clause	Bidder's query	BHEL's clarification
1	Clause No. 2.1.1 & 2.2 of Vol IA TCC, Page 34 Clause No. 10.0 of Vol IA TCC, Page 67	As per these two clauses, the scope with respect to supply of paints is contradictory to each other. If supply of primer & paint is in contractor scope, please clarify which paint systems are to be considered against different product groups (PGMA's) based on design temperature as per painting specification No. 6987-0642-PT-F09 Rev.0	Supply of Paints/Primer/Thinner and application of paints for final painting is in BHEL Scope and all other consumables like brush, cleaning agents etc and all T&P including scaffolding materials, Manpower and supervision is in contractor's scope. Paint/Painting Schemes as per OPaL/EIL Specification for Shop & Field Painting SECTION C: 4.9, SPECIFICATION No. 6987- 0642-PT-F09 Rev 0 part of Technical Specification.
2	Clause No. 14.1.5 of Vol IA TCC, Page No. 130	BHEL shall provide required test coupons to contractor, free of cost. Please confirm.	BHEL will provide the raw materials (free of charge) for preparation of test pieces for conducting the site qualification test of IBR welders . Contractor shall prepare the required test pieces from such raw materials. Contractor shall arrange all the materials and prepare test coupons for site qualification test of all other welders .
3	Clause No. 2.4.1 of Vol IA TCC, Page No.112 Clause No.4.2.2.17 of Vol IB SCC, Page No. 14	Please clarify the scope with respect to arrangement of elevator as it is contradictory as per the referred clauses.	The Clause No.4.2.2.17 of SCC, Page No. 14 is applicable only when BHEL is providing lift/ elevator. But under this contract as per Clause No. 2.4.1, Page No.112 of Vol IA TCC it has been already indicated that Construction lift/elevator is in the scope of contractor. Hence Clause No. 2.4.1 Page 112 of Vol IA TCC supersedes the clause 4.2.2.17 page No. 14 of Vol I B SCC.

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
पावर सेक्टर- पश्चिमी क्षेत्र
श्रीमोहिनी काम्पलेक्स, 345 - किंग्सवे
नागपुर- 440 001



Bharat Heavy Electricals Limited
Power Sector-Western Region
Shreemohini complex, 345 - Kingsway
Nagpur -440 001

फोन / Phone 0712- 3048600 TO 604 फेक्स FAX: 0712- 3048698- 699/ 3048605 www.bhel.com

Ref: BHE/PW/PUR/DHJOI-BLR/966-967/Corrigendum 02

Date 01/03/2012

-----Page 2 of 2-----

BB) Issue of Drawings

Following 3 (three) Drawings are attached along with this corrigendum:

- o Drawing Ref: 0-381-01108 Rev 06: Uploaded as file titled Plot Plan
- o Drawing Ref: 0-00-561-93543 Rev 01 }
o Drawing Ref: 0-00-511-9529 Rev 01 } Uploaded as file titled Drawing

=====
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-02 (Clarification-966-967)" against NIT-11425 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)

Encl: Drawings Three Nos