

To

ALL BIDDERS

Sub: Corrigendum-03: Clarification to the Queries of Bidder and Extension of Last Date of Offer Submission

JOB: FOR HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, CHECKING OF CALIBRATION, TESTING, COMMISSIONING AND HANDING OVER OF CABLING, TRANSFORMER, DAVR, SOOT BLOWER SYSTEM, VARIABLE FREQUENCY DRIVES FOR ID, FANS, BUS DUCTS, SWITCHGEAR, EARTHING AND ASSOCIATED EQUIPMENTS FOR ELECTRICAL PACKAGE OF 2X250 MW LIGNITE BASED BHAVNAGAR THERMAL POWER PLANT AT BHAVNAGAR ENERGY COMPANY LIMITED DISTRICT- BHAVNAGAR, GUJRAT .

Tender Specification Number: BHE/PW/PUR/PDVT-ELE/1132

Bidders to kindly take note of the following:

=====

AA) Clarification to the Queries of Bidder

Sl no	Reference clause of Tender Document	Bidder's query	BHEL's clarification
1	VOL IA, TCC, Cl.No. 2.1.13 / Page 30 of 92	We have noted that, man-hours of rework / modification / repairs etc to be maintained by contractor, However, please let us know the payment procedure of such works from BHEL, which is not mentioned in the clause.	Payment shall be made as per GCC clause no 2.15 of Doc.PS:MSX:GCC:Rev 01.
2	VOL IA, TCC, Cl.No.2.4.11 / Page 38 of 92	Please provide the size wise quantum of LT Power Cable Straight Through Jointing Kit	It is as per the site requirement.
3	VOL IA, TCC, Cl.No.6.1.1 / Page 71 of 92	In sr.no. 5 of schedule of PG Test – Unit#2, there might be a typographical mistake as “May’14” (It should be “May’15”). Please confirm.	PG test – Unit #2 –May 15
4	VOL IA, TCC, Cl.6.4 / Page 71 of 92	Total contract period of 15 months is not matching with schedule given in Cl.6.1.1. Please Clarify. Please provide the month & year of “start of Erection”	The Tentative schedule to start the erection work is July 13.
5	VOL II, Price Bid, Sl.No.E 1.5 & E 1.6 / Page 1 of 8	Size of Perforated tray given in Sr.no.E 1.5 & E 1.6 are same. Please clarify	Sl no E1.5 is 300 mm wide and sl No E1.6 is 150 mm wide.

BB) EXTENSION of LAST DATE:

The last date for submission of Tender has been re-scheduled to **15/05/2013, 15.00 hrs.**

Technical Bid shall be opened on **15/05/2013 at 16.00 hrs.**

=====

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
पावर सेक्टर- पश्चिमी क्षेत्र
श्रीमोहिनी कॉम्प्लेक्स, 345 - किंग्सवे
नागपुर- 440 001



Bharat Heavy Electricals Limited
Power Sector-Western Region
Shreemohini complex, 345 - Kingsway
Nagpur -440 001

फोन / Phone 0712- 3048600 TO 604 फैक्स FAX: 0712- 3048698- 699/ 3048605 www.bhel.com

Ref: BHE/PW/PUR/PDVT-ELE/1132/Corrigendum 03

Date 13/05/2013

-----Page 2 of 2-----

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-03 (Clarification-1132)" against NIT-14084 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)