

Ref: BHE/PW/PUR/DHJOI-CRH/1055/Corrigendum-03

Date 20/10/2012

-----Page 1 of 2-----

To

ALL BIDDERS

Sub: Corrigendum -03 for Issue of Clarifications

JOB: PROVIDING ROUND THE CLOCK SERVICES OF TOWER CRANE ON MONTHLY HIRING BASIS FOR CONSTRUCTION WORK AT OPaL ONGC PETRO ADDITIONS LIMITED SEZ DAHEJ GUJARAT STATE

Tender Specification Number: BHE/PW/PUR/DHJOI-CRH/1055

Bidders to kindly take note of the following:

=====

AA) Clarification to the Queries of Bidder

SI No.	Reference Clause of Tender	Bidder's query/Statement	BHEL's clarification/Statement
1	Min. Working height((Free Standing height –without any lateral support) 45 Meter (Free Standing height –without any lateral support)	We would like to offer cathead tower crane with 60M Jib. Load lifting capacity of approx 2.7T @ 55M Radius, 3T at 50M radius and 6.3T at 25M radius. Please note all mentioned loads are net lifting weight after considering hook block weight etc.. We have inspected the site and crane will be placed in such a way that this offered crane shall meet all your requirements.	Cathead Tower Crane acceptable with 60M Jib. Load lifting capacity of approx 2.7T @ 55M Radius, 3T at 50M radius and 6.3T at 25M radius. Please note all mentioned loads are net lifting weight excluding hook block weight. All other requirement regarding free standing height etc. shall remain unchanged.
2	--	During the operation of the crane if the crane has to be moved from one location to the other location as per requirement of BHEL the crane shall be considered in use.	Yes. Hiring charges shall be considered during shifting period apart from the charge of local shifting, dismantling, re-assembly/erection, load test etc. which shall be paid under relevant item No3 of Price Bid Specification.
3	Clause No. 10.6 (Page 35)	In case services are availed for part of a calendar month, pro-rata payment of Hire Charges for the utilized number of days shall be made by BHEL. Pro-rata daily hire charges shall be calculated as follows. 10.6.1 Pro Rata Daily Hire Charges	Tender Conditions holds good and this clause shall be operated at the time of commencement/ closure of the contract when the contract commences or closes during the intervening days of a calendar month and contractor shall not be entitled for the

Ref: BHE/PW/PUR/DHJOI-CRH/1055/Corrigendum-03

Date 20/10/2012

-----Page 2 of 2-----

SI No.	Reference Clause of Tender	Bidder's query/Statement	BHEL's clarification/Statement
		= Monthly Hire Charges divided by 30 10.6.2 Pro Rata Hourly Hire Charges = Monthly Hire Charges divided by 360	entire monthly charges.
4	---	Further we agree to do the foundation work or chassis as we feel as a better/feasible option during actual installation.	Though we have asked for Flaptop Cross base foundation type of Tower Crane which does not call for massive foundation. Bidders are advised to visit the site and assess the bearing capacity of Soil and if any foundation/plateform with or without piling is required the same shall be done by bidder without any extra cost.

=====
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-03 Issue of Clarifications" against NIT_12845 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)