

To

ALL BIDDERS

**Sub: Corrigendum-05:** Clarification to the Queries of Bidder.

**JOB:** FOR HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, CHECKING OF CALIBRATION, TESTING, COMMISSIONING AND HANDING OVER OF CABLING, TRANSFORMER, DAVR, SOOT BLOWER SYSTEM, VARIABLE FREQUENCY DRIVES FOR ID, FANS, BUS DUCTS, SWITCHGEAR, EARTHING AND ASSOCIATED EQUIPMENTS FOR ELECTRICAL PACKAGE OF 2X250 MW LIGNITE BASED BHAVNAGAR THERMAL POWER PLANT AT BHAVNAGAR ENERGY COMPANY LIMITED DISTRICT- BHAVNAGAR, GUJRAT .

Tender Specification Number: BHE/PW/PUR/PDVT-ELE/1132

Bidders to kindly take note of the following:-

=====

**AA) Clarification to the Queries of Bidder**

| Sl no | Reference clause of Tender Document           | Bidder's query  | BHEL's clarification  |
|-------|---|---|---|
| 1     | VOL II, Price Bid, SI.No.E 6.12 / Page 6 of 8 | As per Corrigendum no. 01, the UOM of this item is "Mtrs", whereas scope given in TCC cl. No. 2.9.10 (Page 48 of 92) is for Earth pits. Hence, please clarify the exact scope of this item. | <b>The earth rods are to be used for below ground earthing.</b>   |
| 2     | VOL II, Price Bid, SI.No.E 5 E / Page 5 of 8  | Description of item is given for Battery Charger. Please clarify for the item of "Battery"  | <b>Battery charger includes batteries system.(total 3 sets to be erected and commissioned )<br/>Details of batteries as follows:<br/>one set of battery consists of 108 cells :<br/><br/>Details of each cell:<br/>1) Dimension (in mm)- 585L X 368W X 682H<br/><br/>2) Weight (in Kg)- (i) with acid- 307.3 Kg<br/>(ii) without acid- 215.9 Kg<br/><br/>3) Rating- 1930 AH</b> |
| 3     | VOL II, Price Bid, SI.No.E 5 E / Page 5 of 8  | Qty. given is 3 sets, where as in TCC, Annexure-II B (Page no. 91 of 92), qty given is 4 sets. Please Clarify.  | <b>Quantity is 3 nos. as per price bid.</b>   |

भारत हेवी इलेक्ट्रिकल्स लिमिटेड  
पावर सेक्टर- पश्चिमी क्षेत्र  
श्रीमोहिनी काम्पलेक्स, 345 - किंग्सवे  
नागपुर- 440 001



Bharat Heavy Electricals Limited  
Power Sector-Western Region  
Shreemohini complex, 345 - Kingsway  
Nagpur -440 001

फोन / Phone 0712- 3048600 TO 604 फैक्स FAX: 0712- 3048698- 699/ 3048605 www.bhelpswr.co.in

Ref: BHE/PW/PUR/PDVT-ELE/1132/Corrigendum-05

Date 17/05/2013

-----Page 2 of 2-----

|   |  |   |                    |
|---|--|---|--------------------|
| 4 | Vol I, TCC, Chapter - II, Clause no. 2.9.15 - 15 / Page 53 of 92 | We assumed that, radiography is with Gamma Ray and NDT is with Dye Penetrant Test. Please confirm | <b>We confirm.</b> |
|---|--|---|--------------------|

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum. This letter is hosted as file titled "Corrigendum-05 (Clarification-1132)" against NIT-14084 in BHEL web page ([www.bhel.com](http://www.bhel.com)→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)