

To
ALL BIDDERS

JOB: RECEIPT OF MATERIALS FROM BHEL / CUSTOMER STORES / STORAGE YARD, HANDLING AT STORES/STORAGE YARD, SITE OF WORK, TRANSPORTATION TO SITE OF WORK, ERECTION, TESTING, ASSISTANCES FOR COMMISSIONING & TRIAL OPERATION, INSULATION, FINAL PAINTING AND HANDING OVER OF **STEAM TURBINE, TURBO-GENERATOR**, CONDENSER AND ASSOCIATED AUXILIARIES INCLUDING BOUGHT OUT ITEMS, ETC. OF 5X270 MW THERMAL POWER PLANT INDIA BULLS **AMARAVATHI PHASE II** UNIT 6 to 10 DEVIDED INTO BLOCK 1(Unit 6, 7 & 10) and BLOCK 2 (Unit 8 & 9).

SI No	Tender Specification Number	Unit Number & Project
1	BHE/PW/PUR/AMRT1-STG U-6,7 & 10/956	270 MW STG Sets of Unit 6, 7 & 10 (Block I)
2	BHE/PW/PUR/AMRT1-STG U-8 & 9/957	270 MW STG Sets of Unit 8 & 9 (Block II)

Bidders to kindly take note of the following:

=====

AA) clarification to the Queries of Bidders

SN	Queries by Bidder	Clarification by BHEL
1	Refer SI No 5 of Corrigendum 03 dated 21/02/2012 Manpower assistance limited to 6 persons will be provided during strand jack erection	The condition of providing 6 persons during assebbly, Installation and commissioning of Strand Jack equipment is not acceptable to BHEL. Manpower deployment in numbers can not be decided at this point of time and bidder has to provide man power assistance in such a way that installation of Strand Jack shall be carried out uninterruptedly
5	Refer SI No 5 of Corrigendum 03 dated 21/02/2012 T&P for Assembly, Installation and desmentaling of Strand Jack Reg: Provision of required crane for assembly, installation and commissioning of Strand Jack lifting system will be in the scope of BHEL	It may be noted that Stator will be lifted from unloading bay. The part of Strand Jack equipment will be unloaded in unloading bay and it will be erected with the help of EOT crane. Other T&Ps will be required as per 'List of T & Ps to be provided by Contractor' in Chapter IV of 'Vol IA TCC'. The heaviest single piece of strand jack equipment to be erected is approx 30 MT.

BB) EXTENSION of LAST DATE:

The last date for submission of Tender has been re scheduled to 30/03/2012, 15.00 hrs.

Technical Bid shall be opened on 30/03/2012 at 16.00 hrs

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-08 (-956-957)" against NIT-11225 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)