

CORRIGENDUM -2 TO TENDER SPECIFICATION BHEL PSSR SCT 1583 - Civil, Structural and Architectural works of Utility Boiler and allied works including Multi Flue RCC Chimney for 1 x 150TPH RESID Upgradation Project at CPCL, Manali, Chennai.

DT:02/05/2015

Some of the bidders sought clarifications vide letters in regard to TENDER SPECIFICATION BHEL PSSR SCT 1583 - Civil, Structural and Architectural works of Utility Boiler and allied works including Multi Flue RCC Chimney for 1 x 150TPH RESID Upgradation Project at CPCL, Manali, Chennai and BHEL's clarifications are furnished below for information.

<u>Sl. No.</u>	<u>Reference</u>	<u>Clarification/Query</u>	<u>BHEL REPLY</u>
1	BOQ item Sl. No. 504 a	Please provide the specification for layer description.	Bidder may refer customer specification
2	BOQ item Sl. No. 10.8	BOQ item Sl. No. 10.7 is missing. Please clarify.	Item description for 10.7 is Supplying, fitting and fixing 150mm dia cast iron "Roof Drain" pipes at various elevations including drain head, shoe bends, junctions, sockets, adapters, brackets, hangers, supports etc jointing, caulking. Prime coat of painting with anticorrosive paint including all materials etc complete as per drawings and specifications.
3	BOQ item Sl. No. 10.16	Please provide the weight of one number S.S. insert / plug	Tentative weight of S.S. insert/lugs may vary 100 kg to 150 kg, however final weight will be available after detail engineering
4		Technical Specifications as per Page Nos. 92, 93 & 108 of Vol-I of Tender Document is not enclosed with Corrigendum No. 1. Hence, it is understood that above Technical Specifications are irrelevant to this Tender and the same may please be considered as null and void. Please confirm.	Accepted
5	BOQ item Sl. No. 6.2	Please provide material specification.	material specification in item no. 6.2 is same as item no. 6.1.

Note:-

All other Terms & Conditions remain unchanged.

GM / HR & SCT