

CORRIGENDUM NO. 5 OF NIT 11048 (HVAC RENOVATION WORKS)

The following new item will be part of Annexure–I (Part A):

Supply of the following items :

- (i) MS B Class pipe 50 mm : 115 mtrs***
- (ii) MS B Class pipe 20 mm : 60 mtrs***
- (iii) Coated Pipe PVC 20 mm : 48 mtrs***
- (iv) Nipple ¾” : 48 Nos***
- (v) Elestomeric closed cell pipe insulation
With sealed properly adhesive and tape: 115 mtrs***

The following new item will be part of Annexure–I (Part B):

- (i) Erection & commissioning of drain of each FCU (61 Nos) to be connected to a common header of 50mm dia and the same shall be connected to existing FCU drain.
Making good all damaged Civil work to the satisfaction of Engineer-Incharge.***