

Ref: BHE/PW/PUR/VNT5-CNI U#13/1354/Clarification/Corrigendum-01

Date 09/12/2014

To
ALL BIDDERS

Sub: Corrigendum-01: Clarification.

JOB: HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, CHECKING OF CALIBRATION, TESTING, COMMISSIONING AND HANDING OVER OF CONTROL & INSTRUMENTATION WORKS FOR BOILER AND ITS AUXILIARIES, TURBOGENERATOR AND ITS AUXILIARIES FOR 1X500 MW VINDHYACHAL SUPER THERMAL POWER PROJECT UNIT NO. -13 AT VINDHYACHAL SUPER THERMAL POWER STATION NTPC LIMITED VINDHYACHAL SINGRAULI, MADHYA PRADESH

Bidders to kindly take note of the following:

AA) Clarification to the Queries of Bidder

SI No	Description / Bidder's query	BHEL's clarification
1	In SI. No. I1.0, (I1.0.1, I1.0.2, I1.0.3) Cable Tray and Accessories, Kindly let us know whether trays are required with cover or without cover.	In few portions trays are required with cover & in few without cover.
2	Price bid, item no I9.0.12 Soot Blower system Commissioning assistance & I9.0.13 Remote Commissioning motorised actuators of subject tender. In Tender Specification No. ELE U#13/1325 (Electrical package) In Price Bid, item no E9.9 Testing & Commissioning of Wall, Long Retractable, Air Heater Soot Blower & E9.12 Electrically (LT) Operated Valves, Dampers and Gates with Actuators, Limit Switches etc. (Regulating & ON/OFF Type). We require clarification of scope available in subject tender.	Scope specified in C & I Package is for remote commissioning (through DCS).
3	In SI. No. I7.0.38 & I7.0.39 of Price Bid, Kindly confirm us whether 17 mtrs & 75 mtrs indicate the length or elevation of the panel.	17 mtrs & 75 mtrs indicate the elevation of the panel

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-01 (Clarification-1354)" against NIT-20459 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)