

पावर सेक्टर- पश्चिमी क्षेत्र Power Sector-Western Region
श्रीमोहिनी काम्पलेक्स, 345 किंग्सवे, नागपुर Shreemohini complex, 345 Kingsway Nagpur - 440 001
फोन / Phone 0712- 3048600, फैक्स FAX: 0712- 3048699 www.bhelpswr.co.in

Ref: BHE/PW/PUR/DHLI-ELE U-1&2/1300/Corrigendum-01

Date 04/08/2014

To
ALL BIDDERS

Sub: Corrigendum-01: Issue of Clarification.

JOB: HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, CHECKING OF CALIBRATION, TESTING, COMMISSIONING AND HANDING OVER OF GENERATOR TRANSFORMER, UNIT AUX. TRANSFORMER, STATION AUX. TRANSFORMER, DAVR, ELECTROSTATIC PRECIPITATOR, SOOT BLOWER SYSTEM, ELECTRICAL HOIST, VALVE ACTUATOR, HT/LT DRIVES COMMISSIONING, CABLING PACKAGE, EQUIPMENT EARTHING AND ASSOCIATED EQUIPMENTS FOR 2X150 MW SINTEX INFRA DHULE Project AT SINTEX INFRA PROJECT LTD 2x150 MW WAGHODE, SHINDKHEDA MAHARASHTRA.

Tender Specification Number: BHE/PW/PUR/DHLI-ELE U-1&2/1300

Bidders to kindly take note of the following:

AA) Clarification to the Queries of Bidder

Sl.No.	Ref. clause of Tender Document	Bidder's query	BHEL's clarification
1	TCC Chapter - II : Scope of Works Clause 2.4.11	To quote most competitive price, kindly provide us the approximate quantity of cable straight through jointing kit.	1) LT joint kit will be in minor qty (approx. 8 Nos.) size cannot be mentioned at this stage.
2	TCC Chapter - II : Scope of Works Clause 2.5.F	Kindly provide us number of coats of primer to be used.	Final painting two coats of paint shall be done as per specification. Two coats Primer painting shall be done only where dents are noticed which will be minor in nature.
3	TCC Chapter - II : Scope of Works Clause 2.9.1.C	To quote most competitive price, kindly provide us the approximate quantity of cable tray accessories like bends / tee / reducers, etc	Readymade bend/Tee shall be supplied by BHEL/Client for erection. In some very few cases ,Wherever ready made bend/Tee are not matching with running tray in such area cutting and machining shall be inclusive in running meter unit rate. Also ,in some few areas vendor may have to fabricate bends/Tee due to any reason (viz,shortage etc.)
4	TCC Chapter - II : Scope of Works Clause 2.7	Please clarify the scope further.	Such conditions will be very few so vendor may quote as per past Experience.
5	General	Kindly provide the approximate distance between BHEL / Client Stores to Work Site.	The distance from work site to BHEL/Client store shall be with in 600 Mtr Distance. In This project Cable tray, accessories, steel support and cables shall be provided by Client.

पावर सेक्टर- पश्चिमी क्षेत्र Power Sector-Western Region
श्रीमोहिनी काम्पलेक्स, 345 किंग्सवे, नागपुर Shreemohini complex, 345 Kingsway Nagpur - 440 001
फोन / Phone 0712- 3048600, फैक्स FAX: 0712- 3048699 www.bhelpswr.co.in

Ref: BHE/PW/PUR/DHLI-ELE U-1&2/1300/Corrigendum-01

Date 04/08/2014

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-01 (Clarification-1300)" against NIT-18656 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)