



Ref: BHE/PW/PUR/KHZI-BLR/988/Corrigendum-01

Date 17/04/2012

To

ALL BIDDERS

JOB: RECEIPT / COLLECTION / LOADING/ UNLOADING / TRANSPORTATION OF MATERIALS FROM BHEL / CLIENT'S STORES/STORAGE YARDS TO SITE OF WORK, ERECTION, TESTING, COMMISSIONING OF 1x190TPH HEAT RECOVERY STEAM GENERATOR & AUXILIARIES, PIPING, CHIMNEY, APPLICATION OF THERMAL INSULATION, FINAL PAINTING, CO-GENERATION OPERATION AND HANDING OVER FOR 1x72 MW CPP REVAMP KRIBHCO HAZIRA PROJECT.

Tender Specification Number: BHE/PW/PUR/KHZI-BLR/988

Bidders to kindly take note of the following:

=====

AA) CLARIFICATION TO THE QUERY OF BIDDER:

QUERY 01: Refer Chapter IV: 'T & Ps and MMEs to be deployed by contractor-item-1No. Crawler Crane, 75T-1 No.' in Vol IA TCC: This Crane is useful only till modules erection. Then why this should be kept at site from start of erection till completion. 75 T Crane cost is too high to load on such a small project. This should be provided as per requirement.

CLARIFICATION OF QUERY 01: Crane to be made available as and when required to carry out E&C work within the period of contract.

QUERY 02: Refer Annexure-1 PGMA 04116: 'Boiler Drum – 90 MT': How many Boiler Drums are there?

CLARIFICATION OF QUERY 02: There is One Boiler Drum. Refer drawing uploaded along with this Corrigendum 01.

QUERY 03: Whether P91 work is involved or not?

CLARIFICATION OF QUERY 03: P91 is not in piping system

QUERY 04: Refer Annexure-1 PGMA: '97411 to 97470 instrumentation work' : Whether calibration of instruments and laying and termination of instrument cables are included in the scope of this work.

CLARIFICATION OF QUERY 04: Items in PGMA 97-411 to 97-470 are C&I items .These items are excluded from the scope of subject tender.

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
पावर सेक्टर- पश्चिमी क्षेत्र
श्रीमोहिनी काम्पलेक्स, 345 - किंग्सवे
नागपुर- 440 001



Bharat Heavy Electricals Limited
Power Sector-Western Region
Shreemohini complex, 345 - Kingsway
Nagpur -440 001

फोन / Phone 0712- 3048600 TO 604 फेक्स FAX: 0712- 3048698- 699/3048605 www.bhel.com

Ref: BHE/PW/PUR/KHZI-BLR/988/Corrigendum-01

Date 17/04/2012

.....
Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum 01 (988)" against NIT-11666 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)
Encl:- Drawing 1 No.