

Ref.: BHE/PW/PUR/ KRSR-BLR/1504/Corrigendum 01
To

DT: 06/08/2015

ALL BIDDERS

Sub: Issue of Corrigendum 01 for issue of Clarification & extension of offer submission date

Job: Collection of materials from BHEL/Client's storage/storage yard, Transportation to site and carrying out Replacement/Erection, Overhauling, Testing, Commissioning, Trial Operation and handing over of Boiler and its Auxiliaries including Air Pre-heaters, Ducts and Dampers, Fans, Fuel Piping, Boiler Integral Piping, Power Cycle Piping, Chemical Dosing System, Lining & Insulation, Final Painting and Transportation of the scrap to scrap yard etc. for the work of Main Plant Package of Energy Efficient Renovation & Modernization (EE R&M), Unit # 6 at MSPGCL, Koradi TPS, Dist.: Nagpur, Maharashtra.

T.S.No: BHE/PW/PUR/ KRSR-BLR/1504

Bidders to kindly take note of the following:

=====

AA) Clarifications to Bidder's queries

<u>Sl No.</u>	<u>Bidder's Query</u>	<u>BHEL's Clarification</u>
1	As per Clause NO.-13.13.37-Wherever hanger & support materials are not received from Manufacturing unit in time to suit erection schedule, the contractor shall erect the systems on temporary supports to ensure the progress of work. The required structural steel materials will be issued on free of charges by BHEL, either from scrap/spare materials. The same shall be removed and returned to BHEL store after erection of permanent supports. In this reference, we understand that payment against Fabrication & Erection of Temporary support is applicable as per sl no.1.6 of price bid & payment for dismantling of temporary support is eligible as per Sl no.2.6 of price bid. Kindly confirm	Erection of regular supplied items for Piping-Hangers and Supports Payable under Price Bid Specification Volume-II, Sl. No.-1.6 and not applicable for temporary supports Also payment for dismantling as Price Bid Specification Volume-II Sl.No.-2.6 not applicable for Temporary Support and approaches. No separate payment will be made for erection & dismantling of temporary supports & to be carried out within the quoted total price.
2	Kindly provide the pipe details viz. Size, Material, Wall thickness, Pipe length etc	As of now, BHEL is not having the specific details as sought. Pipes to be used are existing erected pipes at plant. In case replacement is required, BHEL shall supply on required basis & payment

Ref.: BHE/PW/PUR/ KRSR-BLR/1504/Corrigendum 01

DT: 06/08/2015

		shall be made on Tonnage erected. For the information sought, we advise bidders to visit the site & assess the details.
3	Whether the painting is only for the erected components or as in a whole.	Whole painting of Boiler and Auxiliaries except ESP is to be done by Contractor.
4	Whether the thickness/survey/measurement Equipment will be provided free by BHEL?	Equipment will be provided free by BHEL
5	Whether the equipment required for video inspection to be provided by BHEL or not?	BHEL shall provide the video inspection equipment

BB) Extension of due date for offer submission

**The due date of offer submission has been extended to 13/08/2015, 15.00 HRS.
Technical Bid shall be opened on 13/08/2015 at 16.00 hrs.**

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended
by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by
the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of
this corrigendum.

This letter is hosted as file titled "Corrigendum-01" against NIT-23522 in BHEL web page
(www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)