

Ref.: BHE/PW/PUR/MANUT-STATOR/1559/Corrigendum 01

DT: 09/12/2015

To,

ALL BIDDERS

Sub: Corrigendum 01 for issue of Clarification, issue of drawings & extension of offer submission date.

Job: PROVIDING SERVICES ON TURN-KEY BASIS FOR LIFTING & SHIFTING AND PLACEMENT OF GENERATOR STATOR (4 Nos.) ON ITS FOUNDATION BY MEANS OF STRAND JACK METHOD AT 4x270MW TSGENCO MANUGURU PROJECT DIST KHAMMAM – TELANGANA.

T.S.No: BHE/PW/PUR/MANUT-STATOR/1559

Bidders to kindly take note of the following:

AA) Clarifications to Bidder's queries

SI No.	Bidder's Query	BHEL's Clarification
1	Kindly confirm the height of EOT girder from ground level & redlines of EOT crane	Height to top of EOT girder from ground is 27.35 meter. Please refer the drawing "Cross section of TG Building" issued herewith.
2	Kindly provide the Center of gravity details of stator	Please refer the drawing - "Manuguru Stator CG" for C.G of stator issued herewith.
3	Please confirm the distance b/w lifting trunion & trunion	Refer the drawing - "Generator outline" indicating distance between lifting trunion to trunion-2100, 1050 on both sides from Gen CL issued herewith.
4	Confirm the elevation height of Generator stator foundation	Height of operating floor of Generator is 15.5 meter. Please refer attached drawing "Cross section of TG Building" & 15.5 meter floor plan drawing (Already issued earlier).

BB) Issue of Drawings

As detailed above the following drawings are issued herewith Corrigendum (To be downloaded separately).

- Cross section of TG Building
- Manuguru Stator CG
- Generator outline (With issue of new drawing of Generator, the earlier uploaded drawing of Generator stands cancelled & will not be valid)

Ref.: BHE/PW/PUR/MANUT-STATOR/1559/Corrigendum 01

DT: 09/12/2015

CC) Extension of due date for offer submission

The due date of offer submission has been extended to 17/12/2015, 15.00 hrs .Technical Bid shall be opened on 17/12/2015 at 16.00 hrs.

=====
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum 01" against NIT-25279 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)