

Ref: BHE/PW/PUR/KKRN-STG U # 3/1206/Corrigendum 01

Date 16/12/2013

To

ALL BIDDERS

JOB: COLLECTION OF MATERIALS FROM BHEL/CLIENT'S STORES/STORAGE YARD, TRANSPORTATION OF MATERIALS TO SITE, **ERECTION, TESTING, COMMISSIONING**, APPLICATION OF THERMAL INSULATION, FINAL PAINTING INCLUDING SUPPLY OF PAINTS & PRIMERS, PERFORMANCE TESTING, TRIAL OPERATION AND HANDING OVER OF TG PLANT PACKAGE COMPRISING OF **TURBINES, GENERATOR, MSRs, CONDENSERS** WITH INBUILT FEED WATER HEATER, TG AUXILIARIES, INTEGRAL PIPING INCLUDING HP-MSR-LP STEAM PIPING, TANKS, VESSELS, LP HEATERS ETC. WITH HANGERS & SUPPORTS AND ASSOCIATED VALVES, FITTING ETC. **FOR UNIT-3 OF 2X700 MWe NPCIL KAKRAPAR ATOMIC POWER PROJECT** AS PER TENDER SPECIFICATIONS AT NPCIL (NUCLEAR POWER CORPORATION OF INDIA) KAKRAPAR ATOMIC POWER PROJECT KAKRAPAR, DIST. SURAT, STATE- GUJARAT

Tender Specification Number: BHE/PW/PUR/KKRN-STG U # 3/1206

Bidders to kindly take note of the following:

AA) Clarification to the Queries of Bidder

SI.No.	Bidder's query	BHEL's clarification
1.	Refer Chapter 4, TCC, Tools and Plants to be deployed by contractor, Vide S. No.5, Orbital welding machine (minimum 6 nos.) are to be provided by bidder. The orbital seal welding m/c is a very expensive machine and bidder is asked to provide min. 6 nos. for this. We enquired in the market the agencies that are rendering tube expansion /trimming services do not have this machine. Hence we request BHEL to provide this machine as free issue OR allow us for manual seal welding OR provide the details of agencies/vendors to whom that we can approach for such services	Tender condition remain unchanged and contractor has to abide by them.
2.	Refer Chapter 5, TCC, List of T&P to be provided by BHEL on sharing basis, it is mentioned vide sl. no.4, suitable capacity crane for erection of generator stator and MSR in TG hall will be provided on chargeable basis. We request BHEL to confirm the crane capacity and tentative hire charges per hour. As this has got an impact on the price and we cannot assume the hire charges on our own & load.	Tentative capacity of crane shall be 1350 MT and tentative hire charges will be Rs. 18500 (approx) per hour.
3.	Refer Chapter 5, TCC, List of T&P to be provided by BHEL on sharing basis, under note no.10, it is mentioned BHEL/NPCIL will provide suitable capacity crane / strand jack arrangement for generator stator lifting. We are confused with above dual tender conditions BHEL 10 firmly confirm any one either suitable crane will be provided (or) strand jack arrangement for generator stator lifting.	Tender condition remain unchanged.

Ref: BHE/PW/PUR/KKRN-STG U # 3/1206/Corrigendum 01

Date 16/12/2013

Sl.No.	Bidder's query	BHEL's clarification
4	Refer clause no.22.3.1 (Chapter 22 TCC) the approx. weight and dimensions of MSR components are indicated in Annexule-1. The contractor shall arrange suitable capacity trailer, well in advance, to transport MSR components from storage yard to site. We request BHEL to confirm the suitable trailer capacity and its length, so that we can load for the same. A so we request BHEL to review unloading this MSR near to erection area so that re-handling is avoided.	Contractor to refer tender conditions for weight and dimension details of components and arrange suitable capacity trailer accordingly. Tender condition remains unchanged and contractor has to abide by them.
5	Application of final painting including supply of paints & primers is if Bidder scope. The scope of painting given vide clause no.24.1 of TCC (page 113) is a general one, We request BHEL to provide the detailed painting specification and area of painting equipment and piping to be painted. Such details shall be furnished before bidding not during execution.	These details shall be furnished later during execution of work.

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-01 (Clarification-1207)" against NIT-15730 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)