

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
पावर सेक्टर- पश्चिमी क्षेत्र
श्रीमोहिनी कॉम्प्लेक्स, 345 - किंग्सवे
नागपुर- 440 001



Bharat Heavy Electricals Limited
Power Sector-Western Region
Shreemohini complex, 345 - Kingsway
Nagpur -440 001

फोन / Phone 0712- 3048600 TO 604 फैक्स FAX: 0712- 3048698- 699/ 3048605 www.bhelpswr.co.in

Ref: BHE/PW/PUR/VNT5- STATOR/1228/OJ /Corrigendum-01

Date: 17/02/2014

Page 1 of 1

To

ALL BIDDERS

Sub: Unloading of 1 No. 500 MW generator stator (258 MT) from BHEL's special wagon at railway siding at Vindhyanagar, loading the stator on hydraulic trailer, transportation of stator to TG Hall of UNIT-13 OF 1X500 MW NTPC VINDHYACHAL PROJECT NEAR VINDHYANAGAR DISTRICT SINGRAULI IN MADHYA PRADESH STATE .

T.S.No: BHE/PW/PUR/VNT5- STATOR/1228/OJ

Bidders to kindly take note of the following:

AA) Clarification to Bidder's Query:

Query 1: Kindly confirm, wooden crib with the rollers can be used or not against Hydraulic Trolley ?If not , kindly provide drawings of Hydraulic Trolley.

Clarification: The Wooden crib with roller method is not acceptable. Contractor has to provide Hydraulic Trolley as specified in Tender specification.

BB) Issue of Drawings

Bidders are requested to download the Drawing of Hydraulic Trolley issued along with this corrigendum.

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum & all drawings duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-01 " against NIT-16440 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)