

Ref: BHE/PW/PUR/SAT-DGI /1281/Corrigendum-01

Date: 16/06/2014

Sub: Issue of Clarifications & Time extension.

-----Page 1 of 2-----

To

ALL BIDDERS

Job : Receipt, loading, handling, transportation of the 03 sets of DG sets- 1010 KVA, including all mechanical items, electrical items from BHEL/MPPGCL storage yard to site, unloading at location of the DG building, preparation of foundations of DG set and supporting structure for 30 meters exhaust pipe, erection of 30 meters exhaust pipe with supporting structures, commissioning of DG sets & handing over to the client MPPGCL/ BHEL AT SATPURA 2X250 MW, THERMAL POWER STATION, MPPGCL, DIST- BETUL , MADHYA PRADESH.

T.S.No: BHE/PW/PUR /SAT-DGI/1281

Bidders to kindly take note of the following:

=====

AA) Clarification to bidder's queries.

<u>Sl No.</u>	<u>Bidders Query</u> <u>With reference to the referred tender , Kindly Clarify the followings;</u>	<u>BHEL's Clarification.</u>
1	Details of civil works to be carried out (Such as foundation, making approach road for DG shifting, office construction etc.)	No civil work has to be carried out. Foundations are already available. Only grouting of base plates (8, 12 and 36 mm) would have to be done.
2	Kindly confirm the 30 Mtr exhaust pipe and structures are fabricated or fabrication shall be carried out by the bidder.	Structure has to be fabricated. 300 mm dia pre-fabricated exhaust pipes (Chimney) in 110 running meters available and need to be cut and pre assembled only
3	Please provide details of mechanical items and electrical items & Auxiliaries	Electrical items involved- DG set control panels-3 nos; push button- 10 nos; Alternator main and neutral terminal box-3 nos; DG Auxiliary panel- 3 nos; Power and control cable- 1310 meters (approx); Cable tray-360 meters (approx). Other items- DG set-3 nos, Acoustic enclosure; fuel tank; 60 meters 1" hose connection between DG set and fuel tank; support of exhaust pipe; 48 meters 250 mm dia internal piping; 50 mm insulation and cladding of exhaust pipe.

BB) TIME EXTENSION FOR OFFER SUBMISSION:

The due date & time for submission of Tender has been extended to 20/06/2014 , 15.00 hrs.

Technical Bid shall be opened on 20/06/2014 at 16.00 hrs.

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
पावर सेक्टर- पश्चिमी क्षेत्र
श्रीमोहिनी कॉम्प्लेक्स, 345 - किंग्सवे
नागपुर- 440 001



Bharat Heavy Electricals Limited
Power Sector-Western Region
Shreemohini complex, 345 - Kingsway
Nagpur -440 001

फोन / Phone 0712- 3048600 TO 604 फैक्स FAX: 0712- 3048698- 699/ 3048605 www.bhelpswr.co.in

Ref: BHE/PW/PUR/SAT-DGI /1281/Corrigendum-01

Date: 16/06/2014

Sub: Issue of Clarifications & Time extension.

-----Page 2 of 2-----

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum & all drawings duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-01" against NIT No.18074 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)