

Ref: BHE/PW/PUR/ KRSR-ESP/ 1526/Corr-02

date: 18/09/2015

Page 1 of 2

To

ALL BIDDERS

Sub: Corrigendum-02: Issue of Clarifications & Time extension

Job: Transportation of materials from Customer storage to site of work and carrying out Erection, Testing & commissioning, and Application of Insulation/cladding of Electrostatic Precipitators & Fans (ID, PA & SA Fans) for the work of Main Plant Package of Energy Efficient Renovation & Modernization (EE R&M), UNIT # 6 (210 MW) of MSPGCL, Koradi TPS.

Tender Specification Nos: BHE/PW/PUR/ KRSR-ESP/ 1526

Bidders to kindly take note of the following:

AA) Clarifications to Bidder's queries

<u>Sl No.</u>	<u>Bidder's Query</u>	<u>BHEL's Clarification</u>
1	Refer Clause no. 2.2 & 4.3 of Technical conditions of Contract (TCC), Please confirm the scope supply of T&Ps for E & C of electrical system	Deployment of equipment for Electrical System as per clause no.4.3 is in the scope of Contractor.
2	Refer Clause No. 2..2.19, Chapter II of TCC. Kindly clarify that the fabrication & erection of SS Liners are in bidder's scope or not?	Fabrication of SS Liners is not in bidder scope. Supplied items are to be erected on weight basis.

BB) Extension of due date for offer submission

The due date of offer submission has been extended to 24/09/2015, 15.00 HRS.

Technical Bid shall be opened on 24/09/2015 at 16.00 hrs.

=====
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

Ref: BHE/PW/PUR/ KRSR-ESP/ 1526/Corr-02

date: 18/09/2015

-----Page 2 of 2-----

This letter is hosted as file titled "Corrigendum-02-1526" against NIT-23903 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)