

पावरसेक्टर- पश्चिमीक्षेत्र Power Sector-Western Region  
श्रीमोहिनीकम्पलेक्स, 345 किंग्सवे, नागपुर Shreemohini complex, 345 Kingsway Nagpur - 440 001  
फोन / Phone 0712- 3048600, फैक्स FAX: 0712- 3048699 www.bhelpowersw.co.in

Ref: PW/NGP/PUR/1402007/Corrigendum-02

Date 02/06/2014

To

ALL BIDDERS

**Sub: Corrigendum -02 for amendment in technical specification & Extension in due date of offer submission.**  
**JOB: Procurement of Paints for OPG Kutch site.**

**Tender Enquiry Number: 1402007**

Bidders to kindly take note of the following amendment in Enquiry:

**AA) Amendment in Technical Specification of paints required (Refer Annexure-I of 'Volume-I-Technical bid'):-**

The Annexure-I of 'Volume-I-Technical bid' is amended as follows. Bidders are required to submit this document and quote the offered VOS in the column indicated:-

**ANNEXURE-I (Rev:01)**

No.	DESCRIPTION	SHADE	Min VOS (%)	QUANTIT Y (Ltrs)	VOS Offered By Bidder (%) (* Bidders to quote here)
1.	Synthetic Enamel paint (Long oil alkyd) to IS 2932	Smoke Grey Shade No. 692 of IS-5	35	2800	
2.	Chlorinated Rubber Based Finish Paint	Smoke Grey Shade No. 692 of IS-5	40	14500	
3.	Synthetic Enamel paint (Long oil alkyd) to IS 2932	Black	35	740	
4.	Heat Resistance Aluminium Paint IS 13183 Grade I	Aluminium	30	460	
5.	Aliphatic Acrylic Poly Urethane Paint to IS 13213	Phirozi Blue Shade No. 176 of IS-5	40	600	
6.	Aliphatic Polyester Urethane IS 13213	Smoke Grey Shade No.692 of IS: 5	40	2220	
7.	Synthetic Enamel paint (Long oil alkyd) to IS 2932	White Shade RAL 9002	35	20	
8.	Intermediate Paint- Polyamide Epoxy Paint	Smoke Grey Shade No. 692 of IS-5	50	1120	
9.	Red Oxide Zinc Phosphate Primer (Alkyd Base) Paint to IS 12744	Red Oxide Primer	50	12380	
10.	HB Chlorinated Rubber based Zinc Phosphate Primer	----	40	12540	
11.	Epoxy Zinc Rich to IS 14589 Gr.II	----	35	2220	
12.	Thinner	----	NA	7280	

**\*Bidder to fill the column "VOS Offered By Bidder (%)" of this sheet**

Ref: PW/NGP/PUR/1402007/Corrigendum-02

Date 02/06/2014

Notes:	
1.	Paints should have high glossy finish conforming to the relevant standard.
2.	Thinner & primer should be compatible with paints.
3.	Shelf life should be minimum 12 months from date of receipt at site.
4.	Documents required - Batch test certificate (BTC) and documents conforming shelf life of paint.
5.	Supplier shall deliver the material accompanied with manufacturing Batch test certificate (BTC) issued by QA/QC department of the manufacturer in support of compliance with IS specification. BTC must record the volume of solid (VOS).
6.	Inspection Requirement - Inspection by consignee at project site.
7.	Paint should be supplied in container of 20 Liters capacity.

**BB) Extension of Last Date of Submission:-**

**The due date & time for offer submission has been extended to 07/06/2014, 15.00 hrs.**

**CC) Revised Price Bid (Rev:01) dtd.02/06/2014**

PRICE BID: VOLUME-II specification **has been revised and uploaded as file titled "1402007- Vol-II- Price Bid-Rev-01". Bidders shall note that the price bids shall clearly be superscribed with tender enquiry no. along with "1402007- Vol-II-Price Bid-Rev-01" (as applicable).**

**Bidders may kindly note that, price bid is required to be submitted in the Revised format only (Rev:01). Price bid submitted in any other format / old format is likely to be rejected.**

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

Thanking you,  
Yours faithfully,

Engineer (Purchase)

Encl:- 1402007- Vol-II-Price Bid-Rev-01 dtd.02/06/2014