

Ref: BHE/PW/PUR/KORSR1-ESP Pkg-II/1292/Corrigendum-02

Date 31/07/2014

To  
ALL BIDDERS

**Sub: Corrigendum-02:** Issue of Clarification.

**JOB:** Dismantling of Existing ESP Internals & other components, Disposal of the same to scrap yard, Transportation of materials from Customer storage to site of work and carrying out modifications as required, Erection, Testing & commissioning and Application of Insulation/cladding for the work of **Renovation & Retrofitting of existing Electrostatic Precipitators & ducts for Unit# 1(200MW), Unit#5 (500MW) & Unit# 6 (500 MW) sets AT Korba Super Thermal Power Station-Korba District :Korba, Chhatissgarh**

**Tender Specification Number:** BHE/PW/PUR/KORSR1-ESP Pkg-II/1292

Bidders to kindly take note of the following:

=====

**AA) Clarification to the Queries of Bidder**

Sl.No.	Ref. clause of Tender Document	Bidder's query	BHEL's clarification
1	Chapter- IX Vol IA 'TCC"- BOQ of Electrical Items	In BOQ, Quantity of Stage I 3 X 200 MW and Stage II 3 X 500 MW are given: 1. Confirm whether the given quantities are for all the three units of Stage I and Stage II or for one unit of 200 MW and 500 MW.	Quantities indicated are for 3 units of Stage I and Stage II. Based on the per unit quantities, total weight applicable for the subject tender is indicated as 628 MT in the referred Chapter. However, quantities indicated are indicative. Per Unit Rates for stage I and stage II units are to be quoted separately.
2	Chapter- IX Vol IA 'TCC"- BOQ of Electrical Items SI No E5B.1	As per the clause, ECP's, E&C (Including existing and new ESP) 105 Nos for stage I and 192 Nos for stage II: 1. What does the term 'Existing ESP' means? Please specify the Unit No 2. 105 Nos of ECP is for how many Nos of Stage I Units 3. 192 Nos of ECPs is for how many nos of Units of Stage II	1. Existing ESP means, refurbishment work to be done. 2. 35 Nos (105/3) of ECPs in each unit of Stage I (Unit # 1) 3. 64 Nos (192/3) in each unit of Stage II (Unit # 5 & 6)
3	Chapter- IX Vol IA 'TCC"- BOQ of Electrical Items SI No E1.A: Cable Trays and Accessories	As per E1A.1: Ladder Type 600X120 mm – 1170 Mtrs for Stage I and 2700 Mtrs for Stage II Similarly for E1A.2, E1A.3, E1A.4, E1A.5, E1A.6, E1A.7:  Is the given quantities are for new erection of Unit # 3, 5 & 6	Subject tender is identified as Package II and units identified under Package II are Unit # 1, 05 and 06. Quantity for Unit # 1 is (1170/3) = 390 mtrs. For Unit # 5 & 6 quantity will be 2700/3 = 900 Mtrs each unit

Ref: BHE/PW/PUR/KORSR1-ESP Pkg-II/1292/Corrigendum-02

Date 31/07/2014

4	Chapter- IX Vol IA 'TCC'- BOQ of Electrical Items SI No E10: Fire proof sealing work	As per E.10.1: Fire Proof Sealing in Cables bellow PCC/MCC/EC Cables and E10.2: Fire Proof Sealing in Cables Cut outs Risers/Wall Crossing  1. Who will supply the fire proofing material 2. Tentative area in sq.Mtr for which fire proofing work is to be done	1. Fire Proofing material shall be supplied by BHEL 2. Quantum of fireproofing shall be as per the supplied quantity.
5	Chapter- IX Vol IA 'TCC'- BOQ of Electrical Items SI No E11: Illumination	As per E 11.1: Illumination work at the ESP Top. Stair case, New ESP area, new MCC room and service Transformer 1. Provide the BOQ of Illumination 2. Cable lying for illumination is included in the specified job under this or for cable lying separate payment under Section E 2C will be made?	1. Only dismantled cable of illumination is o be restabilised in existing area. 2. Payment for entire work shall be covered under lump sum amount for electrical items.

**BB) EXTENSION of LAST DATE:**

The last date for submission of Tender has been re scheduled to 05/08/2014, 15.00 hrs.

Technical Bid shall be opened on 05/08/2014 at 16.00 hrs.

=====  
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-02 (Clarification-1292)" against NIT-17078 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)