



Ref: BHE/PW/PUR/SKT-STG U-3,U-4/960-961/Corrigendum-02

Date 15/02/2012

Page 1 of 2

To

ALL BIDDERS

Sub: Corrigendum-02: Revised Technical Specification

JOB: RECEIPT OF MATERIALS FROM BHEL/CUSTOMER STORES/STORAGE YARD, HANDLING AT STORES/STORAGE YARD, SITE OF WORK, TRANSPORTATION BETWEEN STORES AND SITE OF WORK, ERECTION, TESTING, COMMISSIONING, FINAL PAINTING AND HANDING OVER OF **STEAM TURBINE, TURBO-GENERATOR** (INCLUDING ITS RECEIPT AND UNLOADING FROM WAGON/ TRAILER, PLACEMENT IN POSITION AND LIFTING BY STRAND JACK ARRANGEMENT), CONDENSER, STG INTEGRAL PIPING, EXTERNAL/REGENERATIVE ETC. WITH ASSOCIATED EQUIPMENTS/TANKS/VESSELS, FST, HP & LP HEATERS ,DEAERATOR WITH ASSOCIATED PLATFORM, POWER CYCLE PUMPS & ASSOCIATED AUXILIARIES, R.E. JOINTS & B.F. VALVES ETC., LP BYPASS SYSTEM WITH ASSOCIATED AUX., BOUGHT OUT ITEMS AND PEM PACKAGES OF EACH UNITS OF **250 MW AT UNIT 3 AND UNIT 4 OF 2 x 250 MW SIKKA THERMAL POWER STATION** GUJARAT STATE ELECTRICITY COORPORATION LIMITED DIST- JAMNAGAR GUJARAT **AS DETAILED IN TENDER SPECIFICATION.**

SI No	Tender Specification Number	Unit Number & Project
1	BHE/PW/PUR/SKT-STG U-3/960	250 MW STG Set of Unit 3
2	BHE/PW/PUR/SKT-STG U-4/961	250 MW STG Set of Unit 4

Bidders to kindly take note of the following:

AA) REVISED VOLUME IA 'TECHNICAL SPECIFICATION':

Volume IA 'Technical Conditions of Contract' has been revised and Uploaded as File Titled '**Vol IA – Rev 01 dated 15/02/2012**' Bidder's may kindly note that only **Revised Volume IA 'Technical Conditions of Contract' Rev 01 dated 15/02/2012** shall only be used for evaluation.

BB) CLARIFICATIONS TO THE QUERIES:

QUERY 01: Refer Clause 16.2.1' Volume IA 'Technical conditions of Contract': Making Resting foundations/footings to suit the installation of Strand Jack arrangement (as required) is included in Contractors scope. Kindly clarify.

CLARIFICATION TO QUERY 01: Making resting foundations implies only to necessary preparatory work likes chipping etc. Foundation construction is not included in TG Contractor scope.

QUERY 02: Refer Chapter 23, Volume IA 'Technical conditions of Contract': Clarify the scope of 'Spray Insulation on Turbine and Valves

CLARIFICATION TO QUERY 02: Spray Insulation on turbine and valve is a Haridwar vendor supplied item. Application of Spray Insulation is also in Haridwar vendor scope.

QUERY 03: Clarify the scope of 'FST and Deareator' and tonnage of TG Integral Piping

CLARIFICATION TO QUERY 03: FST & De-aerator is not included in TG Scope. TG integral piping tonnage is mentioned in revised Volume IA (as indicated in AA above)

QUERY 04: What is the capacity of EOT crane in TG hall ?

CLARIFICATION TO QUERY 04: Capacity of EOT crane is 90/25 MT



Ref: BHE/PW/PUR/SKT-STG U-3,U-4/960-961/Corrigendum-02

Date 15/02/2012

Page 2 of 2

CC) CORRECTION IN 'NOTICE INVITING TENDER'

Some typographical errors were noticed in Sl No 3.f of 'Explanatory Notes for PQR'(Annexure I of NIT). Same has been corrected in the Revised Volume I A issued under AA above.

DD) EXTENSION of LAST DATE:

The last date for submission of Tender has been re scheduled to 27/02/2012, 15.00 hrs.

Technical Bid shall be opened on 27/02/2012 at 16.00 hrs

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-02 (Revised Vol IA-960-961)" against NIT-11249 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)

Enclosure:

- Revised Volume IA including NIT, uploaded as file titled: Volume I A-Rev 01 dated 15/02/2012