

Ref: BHE/PW/PUR/DHLI-STG/1198/Corrigendum 02

Date 24/12/2013

To

ALL BIDDERS

Sub: Corrigendum-02: Issue of Time extension for offer submission and clarification.

JOB: RECEIPT OF MATERIALS FROM STORES, TRANSPORTATION TO SITE OF WORK, ERECTION, TESTING, COMMISSIONING AND HANDING OVER OF STEAM TURBINE, TURBO-GENERATOR, CONDENSER, TG INTEGRAL PIPING, HP & LP HEATERS, DEAERATOR, WITH ASSOCIATED EQUIPMENTS/TANKS/VESSELS, FST & DEAERATOR, LP BYPASS SYSTEM WITH ASSOCIATED PLATFORM, POWER CYCLE PUMPS & ASSOCIATED AUXILIARIES B.F. VALVES , BOUGHT OUT ITEMS ETC IN 1 & 2 OF 2x150 MW AT SINTEX INFRA PROJECT LTD, WAGHODE, SHINDKHEDA , MAHARASHTRA

Tender Specification Number: BHE/PW/PUR/DHLI-STG/1198

Bidders to kindly take note of the following:

=====

AA) Clarification to the Queries of Bidder

Sl.No.	Bidder's query	BHEL's clarification
1.	Whether HP and IP modules supplied in assembled conditions or separate	This a single cylinder turbine will be dispatched in knocked down condition (separately)
2.	HP, IP rotor weights to be specified	Only one rotor is there, Approx weight 45 Tons
3.	LP module will be supplied in assembled condition or loose parts	LP module will be supplied in loose parts.
4	Capacity of EOT crane may please be specified	Total 2 nos. of 110/20 MT capacity
5	Whether we have to consider the lifting of Generator stator by Strand and jack or not	It will be lifted by EOT Crane. Kindly refer tender document
6	De-aerator tray will be supplied in assembled condition or not	It will not be supplied in assembled condition, it will come in three parts.

BB) EXTENSION of LAST DATE:

The last date for submission of Tender has been re scheduled to 30/12/2013, 15.00 hrs.

Technical Bid shall be opened on 30/12/2013 at 16.00 hrs

=====

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
पावर सेक्टर- पश्चिमी क्षेत्र
श्रीमोहिनी काम्पलेक्स, 345 - किंग्सवे
नागपुर- 440 001



Bharat Heavy Electricals Limited
Power Sector-Western Region
Shreemohini complex, 345 - Kingsway
Nagpur -440 001

फोन / Phone 0712- 3048600 TO 604 फैक्स FAX: 0712- 3048698- 699/ 3048605 www.bhelpswr.co.in

Ref: BHE/PW/PUR/DHLI-STG/1198/Corrigendum 02

Date 24/12/2013

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-02 (Clarification-1198)" against NIT-15749 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)