

Ref. No.: BHE/PW/NGP/PUR/13055 E-Amd-02

Dt:01.11.2013

To,

ALL CONCERNED

**Sub: Amendment to Enquiry No. 13055 E dt.23/10/13 due on 11/11/13 for Supply of foundation bolts for NTPC Mauda site - Amendment-02**

**Ref. : - Enquiry No. 13055E dt.19/10/13**

Dear Sir,

Please refer our subject enquiry for supply of foundation bolts for NTPC Mauda Site.The amendment to Enquiry is as below:

SI.	DESCRIPTION	As per Existing Enquiry	Amendments
01	Requirement as mentioned in Annexure-I	----	<p>1. All the parts i.e. bolt, bearing plates (45mm) &amp; stiffener (12MM) to be welded with each other with full penetration weld between bolt &amp; bearing without any gap as per the drawing.</p> <p>2. Dimension of 25 mm thick washer plate: 160 mm x160 mm Square plate and hole ID: 83 MM.</p> <p>3.Finishing of item 1, 2 &amp; 3 in Annexure-I :-</p> <p>(a). For the portion of Steel surface embedded in concrete, the surface shall be prepared by Manual cleaning and provided with Primer Coat of Chlorinated Rubber based Zinc Phosphate Primer of Minimum 50 micron Dry Film Thickness (DFT).</p> <p>(b). All threaded and other surface of foundation bolts and its materials, insulation pins, Anchor channels, sleeves etc. shall be coated with temporary rust preventive fluid.</p>

All other Terms and Conditions of the Enquiry shall remain un-altered. You are requested to comply with this amendment and submit offers likewise.

**Note:- This amendment along with Revised Annexures -I shall be submitted along with offer in sealed envelope. All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.**

Thanking you,

Yours faithfully,  
**For BHARAT HEAVY ELECTRICALS LIMITED**

Dy. Manager/Purchase