

भारत हेवी इलेक्ट्रिकल्स लिमिटेड  
पावर सेक्टर- पश्चिमी क्षेत्र  
श्रीमोहिनी काम्पलेक्स, 345 - किंग्सवे  
नागपुर- 440 001



Bharat Heavy Electricals Limited  
Power Sector-Western Region  
Shreemohini complex, 345 - Kingsway  
Nagpur -440 001

फोन / Phone 0712- 3048600 TO 604 फैक्स FAX: 0712- 3048698- 699/ 3048605 www.bhelswr.co.in

Ref: BHE/PW/PUR/PIPVG-CRH/OJ/964

Dtd. 03/02/2012

Sub: Corrigendum-02: Issue of clarifications.

Page 1 of 1

**Tender Specification No: BHE/PW/PUR/PIPVG-CRH/OJ/964**

To

ALL BIDDERS

**JOB:-** Providing Services of 1 No. Tower Crane with operation & maintenance crew on hiring basis at GSPC Pipavav Power Company Limited Vill-Kovaya (near Pipavav), Taluka: Rajula, Distt- Amreli, (Gujarat)

Bidders to kindly take note of the following:

=====  
**Clarifications Regarding Services of Tower Crane on Hiring Basis at Pipavav:**

**QUERY 01:** Kindly confirm that apart from the height of 25 mtr. There is 13-15 mtr height available which is required for Tower Head.

**CLARIFICATION TO QUERY 01:** Working Height should be less than 25 m as it will foul with the EOT Girder. But, the working floor is at 12.5 m (Turbine Rotor Centre Line). Hence, the minimum height of the Tower Crane should be 18 m.

**QUERY 02:** Working Radius. We have asked our Principal's regarding confirmation as per your requirements. As per the standard working radius is min. 40 mtr.

**CLARIFICATION TO QUERY 02-**The minimum radius available is 40 m, which is acceptable if the Boom can be dismantled in 3-4 parts to facilitate the work at different portions.

**QUERY 03:** We have asked our Principal's regarding confirmation as per your requirements

**CLARIFICATION TO QUERY 03** - Mentioned in previous point.

**QUERY 04:** We would like to submit that we will provide a brand new crane from China which will take min. 12-14 weeks to mobilize at your site. Hence request to please revise the deployment schedule accordingly. Also please note that a period of 1 month is required for commencement of services after Foundation of crane which is in the scope of BHEL

**CLARIFICATION TO QUERY 04** . Mobilization is required at the earliest. As mentioned in the mail, the minimum period required is 12-14 weeks, which will fail the very basis Purpose of the crane deployment. The crane may please be mobilized in a Month's time or earlier.

=====  
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

Thanking you,

Yours faithfully,

AGM (Purchase)