

Ref.: **BHE/PW/PUR/ KRSR-BLR/1504/Corrigendum 02**
To

DT: 11/08/2015

ALL BIDDERS

Sub: Issue of Corrigendum 02 for issue of Clarifications

Job: Collection of materials from BHEL/Client's storage/storage yard, Transportation to site and carrying out Replacement/Erection, Overhauling, Testing, Commissioning, Trial Operation and handing over of Boiler and its Auxiliaries including Air Pre-heaters, Ducts and Dampers, Fans, Fuel Piping, Boiler Integral Piping, Power Cycle Piping, Chemical Dosing System, Lining & Insulation, Final Painting and Transportation of the scrap to scrap yard etc. for the work of Main Plant Package of Energy Efficient Renovation & Modernization (EE R&M), Unit # 6 at MSPGCL, Koradi TPS, Dist.: Nagpur, Maharashtra.

T.S.No: BHE/PW/PUR/ KRSR-BLR/1504

Bidders to kindly take note of the following:

=====

AA) Clarifications to Bidder's queries

<u>Sl No.</u>	<u>Bidder's Query</u>	<u>BHEL's Clarification</u>
1	Please confirm that the Water wall " S" Panel & Goose Neck will be in loose tubes or in assembled panel.?	S" Panel & Goose Neck will be in assembled panel
2	Whether the aux. viz. Fan, PA Fan, seal air fan & Scanner Fan etc. are included in scope of work?	E & C of ID Fan, PA Fan, and seal air fan are not included in scope of work. Which shall be awarded as separate contract as part of ESP Pkg.
3	Approximate quantity of paint required for painting boiler & auxiliaries?	This detail is not available as on date. However bidder may require to supply paint at par with quantity required for 210 MW Thermal Power Plant excluding ESP.
4	Lubricants required for auxiliaries are supplied by BHEL or is to be arranged by bidder?	Lubricants required for auxiliaries are supplied by BHEL
5	Consumables for acid cleaning are in the scope of BHEL or Contractor?	Chemicals for acid cleaning shall be provided by BHEL. Any other consumables will be in contractor's scope.
6	Hydro Ejector for pent House cleaning will be supplied by BHEL or not?	Hydro Ejector for pent House cleaning will be in Bidder scope
7	Whether Electrical & C&I works of smart soot blowing are in scope of Bidder?	Electrical & C&I works of smart soot blowing are not included in scope of works.
8	Whether C & I / Electrical / Pneumatic arrangements for all Gates & Dampers is in scope of bidder?	C & I / Electrical / Pneumatic arrangements for Gates & Dampers are not in contractor's scope.

Ref.: BHE/PW/PUR/ KRSR-BLR/1504/Corrigendum 02

DT: 11/08/2015

9	Please confirm that the equipments & experts for video scope inspection & thickness survey of 12000 points will be arranged by BHEL or not?	Equipments & experts for these works shall be arranged by BHEL. However contractor is required to provide all assistance to carry out these jobs.
---	---	---

=====
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-02" against NIT-23522 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,
faithfully,

Yours

AGM (Purchase)