



**OPEN TENDER ENQUIRY FOR CONTROL VALVE FOR 1X 800 MW GSECL
WANAKBORI STPP UNIT 8**

Ref No. : PE/PG/WAN/E-5078/2015

Date: 18.11.2015

CORRIGENDUM/ ADDENDUM-02

Tender Enquiry no.: PE/PG/WAN/E-5078/2015

Enquiry date: 15.10.2015


DUE DATE
21 NOV 2015
10.00 AM

The body material for following control valves has been revised as per details given below:

S.No.	Description	Tag No.	Technical Specification Reference	Existing Body Material	Revised Body Material
1	GSC MIN. FLOW RECIRCULATION	CDV-40	PAGE 62 OF 169	A216 WCB	A217 WC6
2	EXCESS RETURN TO CST	CDV-46	PAGE 64 OF 169	A216 WCB	A217 WC6
3	CONDENSATE SPRAY TO FLASH TANK-B	CDV-67	PAGE 66 OF 169	A216 WCB	A217 WC6
4	CONDENSATE FOR VALVE GLAND SEALING	CDV-72	PAGE 68 OF 169	A216 WCB	A217 WC6

The bidders who have already submitted their bids for the said tender enquiry, may go through the corrigendum and in case it is felt required, may furnish revised bid with envelopes duly superscribed as "Revised bid (only to be considered)".

All bidders are requested to visit the website www.bhel.com (Tender Notifications Section) OR www.bhelpem.com, all future corrigenda/addenda, if any, for this tender shall be hosted only on above websites.


Md. Mazhar Wahab,
Sr. Engineer, PG-1-1,
BHEL PEM, Noida

Please reply to:

Md. Mazhar Wahab, Sr. Engineer/ Gaurav Jain, Dy. Mgr

PGI-I, BHEL-PEM,
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
Noida-201301 (U.P.)
Tel No. 0120-4213606/4368835