

Ref.: BHE/PW/PUR/ MANUT-CWP/1505 & 1511 /Corrigendum 03

DT: 21/09/2015

To

ALL BIDDERS

Sub: Issue of Corrigendum 03 for issue of Clarification & time extension for offer submission

Job: COLLECTION OF MATERIALS FROM BHEL/CLIENT'S STORES/STORAGE YARD; TRANSPORTATION TO SITE, ERECTION, TESTING & COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF CW PIPING, INCLUDING BUTTER FLY VALVES, FITTINGS, HANGERS, SUPPORTS ETC & WRAPPING & COATING WITH 4 MM TAPE AS PER IS STANDURDS, FINAL PAINTING (INCLUDING SUPPLY OF PAINT, WRAPPING & COATING) ETC. FOR BLOCK I (UNIT 1 & 2) AND BLOCK II (UNIT 3 &4) OF 4X270 MW MANUGURU THERMAL POWER PROJECT.

T.S.No: BHE/PW/PUR/ MANUT-CWP BLOCK I/1505 & BHE/PW/PUR/ MANUT-CWP BLOCK II/1511

Bidders to kindly take note of the following:

=====

A) Clarification to Bidder's Queries

| <u>Sl No</u> | <u>Clause Reference</u> | <u>Bidder's Query</u> | <u>BHEL's Clarifications</u> |
|---------------------|---|---|---|
| 1 | Volume - I: Technical Conditions of Contract (TCC). Chapter-II: Scope of Work Clause 2.0 | kindly confirm the length of readymade spiral welded pipe | Please refer Annex-I of TCC (Technical conditions of contract) of Vol I-A-1505 |
| 2 | Volume - I: Technical Conditions of Contract (TCC). Chapter-XIII: Welding, Radiography, NDT, PWHT Clause 13.3.6 | W.r.t the existing provision -100% radiography of certain sizes in piping has to be taken as per BHEL standards/drawings". Pls confirm the followings; i) What are those certain sizes are. ii) And also clarify what will be the radiography percentage apart from these sizes. iii) Further please confirm that " No PWHT is applicable as the thicknesses are below 19mm" | Clarification sought will be regulated as per BHEL FQP (Field quality plan)/Field welding schedule prepared by BHEL's Manufacturing units. Which will be provided during execution of contract. |
| 3 | | As per industry practice for CW piping, Ultrasonic test can be done for welding instead of radiography | Shall be as per BHEL FQP (Field quality plan)/Field welding |

Ref.: BHE/PW/PUR/ MANUT-CWP/1505 & 1511 /Corrigendum 03

DT: 21/09/2015

| | | | |
|--|--|---|--|
| | | test. So please confirm whether we can use Ultrasonic Test in place of Radiography Test or not. | schedule provided during execution of contract. |
|--|--|---|--|

B) Extension of due date for offer submission

The due date of offer submission has been extended to 28/09/2015, 15.00 HRS. Technical Bid shall be opened on 28/09/2015 at 16.00 hrs.

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-03" against NIT-23539 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)