

Ref: BHE/PW/PUR/TENDHE-STG+MMS/1395/Corrigendum-04

Date 04/03/2015

To

ALL BIDDERS

**Sub:** Corrigendum-04: Clarification and Time Extn.

**JOB:** RECEIPT OF EQUIPMENT/ MATERIAL AT SITE, UNLOADING, INSPECTION, VERIFICATION, REPORTING SHORTAGES / DAMAGES, STORAGE, UP-KEEPING DURING STORAGE, COLLECTION OF MATERIALS FROM BHEL/CLIENT'S STORES/STORAGE YARD; TRANSPORTATION TO SITE; ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION OF SURFACE CONDENSER, STEAM TURBINE, GENERATOR, PIPING, PUMPS & AUXILIARIES INCLUDING ELECTRICAL AND CONTROL & INSTRUMENTATION EQUIPMENTS / COMPONENTS, APPLICATION OF THERMAL INSULATION, FINAL PAINTING, ASSISTANCE FOR PG TEST ETC. AND HANDING OVER OF **2X40 MW STG SET AT TENDAHO NEW SUGAR FACTORY, AFAR REGIONAL STATE, ETHIOPIA**

Bidders to kindly take note of the following:

**AA) Clarification to the Queries of Bidder**

SI No	Description / Bidder's query	BHEL's clarification
1	Refer Clause 3.1.1 g of Volume IA TCC regarding, fencing of storage area, office, canteen etc of the bidder. Please confirm the Sq mtrs of fencing Area & supply of material for fencing.	Supply of fencing material shall be in contractor's scope. Quantity of fencing material shall depend on how best contractor optimizes space utilization. However, Customer's all round fencing shall be there.
2	Refer Clause 3.2.1 of Volume IA TCC regarding Electricity for Construction purpose. Please confirm whether the construction power is chargeable or free.	Electricity supply shall be free. However in view of frequent power failures and to ensure smooth project work, contractor is expected to maintain suitable rating DG set.
3	Refer Clause 3.2.2 of Volume IA TCC regarding Electricity for Office, Stores Canteen etc. Please confirm whether the Electricity is chargeable or free.	Electricity supply shall be free. However in view of frequent power failures and to ensure smooth project work, vendor is expected to maintain suitable rating DG set.
4	Refer Clause 3.2.2 (a) and 3.2.1 (a) of Volume IA TCC regarding Single Point Source. Please confirm the approximate distance of the Single Point source.	At a maximum distance of 200 mtrs from site.
5	Refer Clause 9.L.1.D of Annexure I of Volume IA TCC regarding RCC Cooling Tower. Please confirm the scope of civil works of cooling tower.	Only civil works like chipping of foundations/ non shrinkable cement grouting of fans/ gear box/ motor etc is Vendor scope work including supply of material.
6	Refer Clause 2.01 of Volume IA TCC regarding MM activities. Please confirm whether BHEL will provide any crane for the same.	BHEL shall not provide any crane, T&P etc.
7	Refer Clause 15.B.4 of Volume IA TCC regarding supply of shims and packer plates. Please confirm scope of supply of shims and packer plates. Please note that as per Clause 15.B.9, it is indicated that	Additional SS shims (0.05 mm to 1 mm range) as required for fine alignment of equipment are in contractor scope to supply.

Ref: BHE/PW/PUR/TENDHE-STG+MMS/1395/Corrigendum-04

Date 04/03/2015

	Shims and packer plates is scope of supply by BHEL	
8	Refer Clause 15.C.1 of Volume IA TCC Lubricants for STG and other rotating Auxl for oil flushing, initial fill up and subsequent topping to be arranged by Contractor. However in clause 4.1.9 of SCC, all lubricants and chemicals is in BHEL scope. Please confirm the scope of supply of Lubricants	In BHEL's scope.
9	Please clarify the scope of supply of Insulation	In BHEL's scope.

### **BB) Extension of Last Date**

The last date for submission of Tender has been re scheduled to 09/03/2015, 15.00 hrs.

Technical Bid shall be opened on 09/03/2015 at 16.00 hrs

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-04 (Clarification & time Extn-1395)" against NIT-21278 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)