

Ref: BHE/PW/PUR/WNT2-CVL AHP/1638/Corr-05

Date 05/07/2016

-----Page 1 of 2-----

To,

ALL BIDDERS,

**Sub: Corrigendum-07: Issue Of Clarifications.**

**Job:** Civil and Architectural work for Ash Handling plant (AHP area package-I) including final micro level grading, backfilling up to required level and handing over of all foundations/buildings/structures to structural/mechanical/electrical agencies and final handing over to customer for onward operation purposes AT 1X800 MW Thermal Power Station, Wanakbori, Distt- Kheda, Gujarat.

**E-Tender Specification Number:** BHE/PW/PUR/WNT2-CVL AHP/1638

**Previous Corrigendums Ref:**

Corrigendum Ref	Corrigendum Date	Pertaining to
Corrigendum-01	10/06/2016	Amendment for Pre-Qualification Criteria (Assessment of Capacity of Bidder)
Corrigendum-02	14/06/2016	Amendments regarding Definition of "Industrial Projects" of Technical PQR-B (Annexure-1 of NIT) and Clauses 8.1.1 & 8.1.2 of Chapter-8 of Vol-IA TCC i.e. Taxes, Duties & Levies.
Corrigendum-03	17/06/2016	Extension in due date of offer submission.
Corrigendum-04	27/06/2016	Issue of clarifications

**Bidders to kindly take note of the following:**

**AA): Amendments in item description for item no 704 and 704 A of Part-B of "CHAPTER XI- BILL OF QUANTITY AND % WEIGHTAGES FOR ITEM RATES W.R.T TOTAL LUMPSUM PRICE" (Page No-8 of 26):**

Item SI No	Existing item Description	Amended Nos as
704	Transportation from store and erection, installation and alignment of mild steel foundation bolt assembly conforming to IS:2062 and grade1 of IS:432 in concrete along with nuts, lock nuts (as per IS:1363, 1364 and IS:3138), washers, anchor plates, stiffner plates, protective tape, pipe sleeves, templates etc. including welding, etc. all complete with protective coating as per specification.	<b>Supply, Fabrication, transportation, delivery at site and erection, installation and alignment of mild steel foundation bolt assembly conforming to IS:2062 and grade 1 of IS:432 in concrete along with nuts, lock nuts (as per IS:1363, 1364 and IS:3138), washers, anchor plates, stiffner plates, protective tape, pipe sleeves, templates etc. including welding, cutting, grinding, threading, drilling etc. all complete.</b>
704 A	Fabrication, transportation, delivery at site and erection, installation and alignment of mild steel foundation bolt assembly conforming to IS:2062 and grade 1 of IS:432 in concrete along with nuts, lock nuts (as per IS:1363, 1364 and IS:3138), washers, anchor plates, stiffner plates, protective tape, pipe sleeves, templates etc. including welding, cutting, grinding, threading, drilling etc. all complete.	<b>Transportation from store and erection, installation and alignment of mild steel foundation bolt assembly conforming to IS:2062 and grade1 of IS:432 in concrete along with nuts, lock nuts (as per IS:1363, 1364 and IS:3138), washers, anchor plates, stiffner plates, protective tape, pipe sleeves, templates etc. including welding, etc. all complete with protective coating as per specification.(BHEL will supply Fabricated material free of Cost as Per TCC)</b>

Ref: BHE/PW/PUR/WNT2-CVL AHP/1638/Corr-05

Date 05/07/2016

-----Page 2 of 2-----

**BB) Extension of Last Date**

The last date for submission of Tender has been re scheduled to 11/07/2016, 15.00 hrs.

Technical Bid shall be opened on 11/07/2016 at 16.00 Hrs.

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

**BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL <https://bheleps.buyjunction>**

**BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.**

Thanking you,

Yours faithfully,

AGM (Purchase)