

Bharat Heavy Electricals Limited
(A Government of India Undertaking)
Transmission Business Group, Materials Management



Tower-A ,5th floor
Advant Navis IT Business Park
Plot No. 7, Sector-142, Expressway Noida,
Noida- 201305

SUBJECT- Corrigendum-1 TO NIT No.17329

DATE 01.05.2014

- | | | | |
|----|--------------------|---|-----------------------------|
| 1. | Project | : | APGENCO RAYALSEEMA |
| 2. | Equipment / Item | : | 11 TR Air-Cooled Package AC |
| 3. | Enquiry No. / Date | : | 343E394 dated 17.04.2014 |

With reference to the above NIT, please note that **“Indoor Units will be placed in AHU Room. Outdoor Units will be placed on Roof top. Indoor unit and outdoor units will be connected through interconnecting copper refrigerant pipe. Distance between indoor unit and outdoor units will be 10 mtrs. Vendors may estimate the quantity of interconnecting refrigerant copper piping and consider the same in their offers.”**

All other terms and conditions of tender shall remain same. Kindly ensure to submit your offer as due.

(Rajiv Ranjan)
Dy. Manager (TBMM)