

CORRIGENDUM-1 TO TENDER NOTICE BHEL PSSR SCT 1535,dated:18/10/2013

Some of the bidders sought clarifications in the Tender Specification BHEL PSSR SCT 1535 - Bellary,unit-3, 1x700MW Erection and Commissioning of Power Cycle Piping.BHEL reply for the clarifications sought are furnished below for information.

S.No	Ref No	Bidder's Query	BHEL Reply
1	Clause 1.6.1.1 and 1.6.3 of part-1 Chapter-VI,Time Schedule of TCC	The entire work ofwork at site Start of erection Dec 2013 Steam Blowing July 2014 Synchronisation Aug 2014 Cl 1.6.1.1 indicated the completion period as 15 months whereas in cl 1.6.3 indicates that steam blowing is to be completed in 7 months and synchronisation in 8 months.This seem to be wrong,please clarify	The tender condition prevails .The contract duration indicated in the tender is inclusive of trial operation,handing over and completion of pending points .
2	TCC Page 87/88,CL:1.16.22/1.16.32	MS&HRH strainers erection by other agency including strainer elements.During commissioning cleaning of the filter is in the scope.Scope clarification required	This is excluded from the scope of work
3	TCC page- 87/89/90/911.1 6.24/1.16.37/1.16.45/1.16.52	Commissioning assistance Upto what time period contractor responsibility.if commissioning delay due to BHEL/Customer then what is contract obligation.	Refer the clause 1.16.45 for the period of providing commissioning assistance by contractor. If any Delay in commissioning of the unit is attributable to BHEL will be dealt with the relevant clauses like 2.7.7,2.11 & 2.12 in GCC on case to case basis.
4	Volume II price bid Sr No:1E	For hanger and supports.....Misc items. Please confirm the breakup of tonnage of following items 1.Auxiliary steel and what quantity is to be fabricated 2.Hanger supports 3.Tank,vessels,pumps and misc items 4.Also confirm whether tanks,vessels are to be fabricated?	Refer the Weight shedle in Chapter -9 in TCC
5	Volume II price bid Sr No:3 of note-2 schedule	Tenderers are requiredno to be entertained The space given for writing in words is too small,please confirm that the same proforma can be typed again for filling the rates as well as amount in words.	Tender conditions prevail
6	Cl 23 of NIT	We like your confirmation to submit offer on consortium bidding (with technical tie) as confirmed in Clause 23 of NIT.Please confirm the procdure for submitting PQR for prime bidder and Tie party,the qualification of tie party having boiler approval licence also to be submitted.Please confirm whether approval to be taken from customer for consortium bid submission before of the offer on the due date of the tender along with techno commercial bid Opening	Please refer"F"in Annexure -1 of NIT that Consortium bidding is not allowed for this tender.Stand alone bid only will be considered.

S.No	Ref No	Bidder's Query	BHEL Reply
7	Nil	In respect of supply of filler wire for P91 piping and other piping for HP/LP piping to be supplied by BHEL	TIG filler wires indicated in the welding schedules will be supplied by BHEL manufacturing units will be issued free of cost to contractor. The qty is indicated in chapter -9 of TCC- Weight Schedule in detail under PGMA 80-992 Imported electrodes. If any additional requirement is to be arranged by the contractor within the quoted rates
8	Nil	We request you to indicate type of supports of fabricated and erected for all services	Please refer Clause 1.13.34 of TCC
9	Nil	We request you to indicate the length of piping size wise and service wise for P-91/HP/LP piping and piping for other services	Please refer chapter -9 of TCC- Weight Schedule and quote for the rates against the quantities indicated in MT in the price bid. However the erection drawings will be issued during execution of the work at site.
10	Nil	Request to indicate No of fittings to be considered service wise /size wise	Please refer cl 1.13.21 of TCC & chapter -9 of TCC- Weight Schedule and quote for the rates against the quantities indicated in MT in the price bid. However the erection drawings will be issued during execution of the work at site.
11	Nil	Hydro testing to be considered for pipelines duly erected for each services	Refer CL 1.16.5 of TCC
12	Nil	We request issue the drawings against each services as indicated in the bill of material	Please refer chapter -9 of TCC- Weight Schedule and quote for the rates against the quantities indicated in MT in the price bid. However the erection drawings will be issued during execution of the work at site.
13	Nil	Please confirm whether thickness checking also to be carried out on free issue pipes before starting fabrication and erection.	Identifying and Ensuring the relevant thickness pipes supplied in running meters as per the drawing is in the scope of work
14	Nil	Please also confirm the length of pipes to be supplied in R/L of particular length wise	Please refer chapter -9 of TCC- Weight Schedule and quote for the rates against the quantities indicated in MT in the price bid. However the erection drawings will be issued during execution of the work at site.
15	Nil	We request you to consider Extension of Due Date of Submission upto 01.11.2013	We regret to inform you that we are unable to extend the bid submission date for the subject tender due to administrative reasons. Hence, we request you to submit your offer as per the schedule indicated in the tender.

ALL OTHER CONDITIONS REMAIN UNCHANGED. BIDDERS ARE REQUESTED TO SUBMIT THE CORRIGENDUM WITH DULY SIGNED SINCE THIS FORM PART OF TENDER .

GM/HR&CONTRACTS