



Bharat Heavy Electricals Limited
Industry Sector, Transmission Business Group
Materials Management
Integrated Office Complex
Lodhi Road, New Delhi-110 003
Telephone : 011-41793456
E-mail : dghosh@bhelindustry.com

SUBJECT- Corrigendum-2 TO NIT No.13209

DATE 28.12.2012

- | | | | |
|----|--------------------|---|---|
| 1. | Project | : | PGCIL, N.E. AGRA HVDC |
| 2. | Equipment / Item | : | Air-conditioning Equipment
(Package-B) |
| 3. | Enquiry No. / Date | : | 342E313 Dtd. 26.11.2012, Due on : 04-Jan-13 |

With reference to the above NIT, "Annexure (PBD)-B4 Page 1 / 2" as mentioned in PQR for Air-conditioning & Ventilation System enclosed.

All other terms and conditions of tender shall remain same. Kindly ensure to submit your offer by due date.


(Dibyendu Ghosh)
Sr. Manager (TBMM)

1

Inspection Level & MQP Requirement(For On -shore Supply)

144

Item	Requirement of MQP	Inspection Level
Circuit Breakers	Yes	IV
Isolators/earth switch	Yes	IV
Current Transformers	Yes	IV
Tuning CTs	No	II
Capacitive voltage Transformers	Yes	IV
Filter Capacitors	Yes	IV
Surge Arrestors	Yes	III
PLCC equipments Viz. PLCC Terminal, Protection Coupler, Coupling Device, Wave Trap but excluding EPAX / HF Cable	Yes	III
Control & Relay Panels and Sub-Station automation system	Yes	III
Power Cables	Yes	III
Control Cables	Yes	III
All Transformers	Yes	IV
Oil filled reactor	Yes	IV
Transformer/reactor oil	--	III
Fire Protection System		
a) Pumps, Motors, Engines, compressors and their spares	No	III
b) Panels, Hydro pneumatic tank, strainers, Extinguishers, Conventional Fire Alarm Panels and Pipes	No	II
c) Others	No	I
Ac and Ventilation System 0. (Split Units)	No	II
a) Control Panels GI Sheets for ducting	No	III
b) Chilling unit, AHU, Fans, pumps, motors, MS & GI pipes	No	II
c) others	No	I
LV/MV Switchgear (AC and DC DBs)	Yes	III
Steel Structure (Lattice / Pipe)	Yes	III
Earthing	Yes	III
Bus Post Insulators	Yes	III
Disc Insulator	Yes	IV
AAC/ ACSR Conductor	Yes	IV
Clamps & Connectors / Spacers	Yes	III
Bay Marshalling box/ Lighting Panels/ lighting Switch Boards	No	II
String Hardware	Yes	IV
Cable lugs & Glands	No	I



Pre-award discussion/

10/13

± 800 KV, 6000 MW HVDC MULTI TERMINAL SYSTEM PACKAGE ASSOCIATED WITH NER/ER— NR/WR INTERCONNECTOR-I PROJECT (SPECIFICATION NO. C-61901R-S056-8).

Handwritten signatures and stamps at the bottom of the page, including a circular stamp of BHEL Transmission Business Group, Industry Sector, New Delhi-3.